
Exova Warringtonfire Holmesfield Road Warrington WA1 2DS United Kingdom

T : +44 (0 1925 655116 F : +44 (0) 1925 655419 E : warrington@exova.com W: www.exova.com



BS 6387: 1994



Specification For Performance Requirements For Cables Required To Maintain Circuit **Integrity Under Fire Conditions**

A Report To: Giza Cables Co. Energya

Document Reference: 322002

Date: 4th October 2012

Issue No.: 1

Page 1





Registered Office: Exova (UK) Ltd, Lochend Industrial Estate, Newbridge, Midlothian EH28 8PL United Kingdom. Reg No.SC 70429 This report in issued in accordance with our terms and conditions, a copy of which is available on request

0249



Executive Summary

Objective To determine the performance of the following cable when it is subjected to the conditions of test specified in BS 6387: 1994.

Generic Description	Product reference	Diameter	Weight per unit length
Electricity power cable	"GIZA CABLES - ELSEWEDY 1 X	34.5mm	3.55kg/m
	300 MM2 0.6 / 1 KV		
	CU/MICA/XLPE/SWA/LSHF 2012"		
Please see pa	age 5 of this test report for the full des	scription of the	product tested
Test Results: V	Giza Cables Co. Energya, Giza Cables E Kelo, 28 Misr-Alex Desert Road, Giza City Vhen tested in accordance with BS 63 Pable meets the criteria for Categories (y, Egypt 87: 1994: Secti	
n	t should however, be noted that in the c nounted in accordance with the proce Part 1:1997.		• •
Date of Test 1	4 th , 18 th & 19 th September 2012		

Signatories

in Menus **Responsible Officer** Authorised T. Benyon * S. Deeming * **Technical Officer Operations** Manager

* For and on behalf of Exova Warringtonfire.

Report Issued: 4th October 2012

2012

This version of the report has been produced from a .pdf format electronic file that has been provided by **Exova Warringtonfire** to the sponsor of the report and must only be reproduced in full. Extracts or abridgements of reports must not be published without permission of **Exova Warringtonfire**.

Document No.: 322002 Author: T. Beny

Client:

T. Benyon Giza Cables Co. Energya Page No.: Issue Date: Issue No.:





CONTENTS PAGE NO. EXECUTIVE SUMMARY 2 SIGNATORIES. 2 TEST DETAILS. 4 DESCRIPTION OF TEST SPECIMENS. 6 TEST RESULTS 8 REVISION HISTORY 9

Document No.:322002Author:T. BenyClient:Giza Ca

322002 T. Benyon Giza Cables Co. Energya Page No.: Issue Date: Issue No.:





Test Details

Purpose of test	To determine the performance of a specimen of a cable when it is subjected to		
	the conditions of test specified in BS6387: 1994 "Specification for performance		
	requirements for cables required to maintain circuit integrity under fire conditions".		

The tests were performed in accordance with the procedures specified in BS 6387: 1994: Sections D.2, D.3 and D.4 and this report should be read in conjunction with that Standard.

Table 1, contained within Clause 6 of BS 6387: 1994 states that for Category Z (resistance to fire and mechanical shock) tests, a cable having a diameter greater than 20mm cannot be accommodated utilising the "Z" shaped specimen support. The standard further states that guidance on testing these cables should be sought from the manufacturer.

In the case of the Category Z test, the cable specimen was mounted in accordance with the procedure detailed in Annex E.2 of BS 7629: Part 1:1997.

Scope of test BS 6387: 1994 specifies methods of test for resistance to fire, resistance to fire with water and resistance to fire and mechanical shock. The specification recommends three test categories which are as follows: -

Resistance to fire alone (Section D.2): Tests are carried out at

	<u>Symbol</u>
650°C for 3 hours	А
750°C for 3 hours	В
950°C for 3 hours	С
950°C for 20 minutes	S
Resistance to fire with water (Section D.3):	

Resistance to fire and mechanical shock (Section D.4): Tests are carried out at

	<u>Symbol</u>
650 ⁰ C	Х
750 ⁰ C	Y
950 ⁰ C	Z

Document No.:322002Author:T. BenyonClient:Giza Cable

T. Benyon Giza Cables Co. Energya Page No.:4 of 9Issue Date:4th October 2012Issue No.:1





At the request of the sponsor, tests in accordance with the procedures defined in Section D.2 (at a temperature of 950° C and rated voltage of 1000V-rms for a period of three hours), Section D.3 and Section D.4 (at a temperature of 950° C and rated voltage of 1000V-rms for a period of fifteen minutes) of the standard have been performed to determine compliance with the requirements of Categories C, W & Z.

- **Fire test study group/EGOLF** Certain aspects of some fire test specifications are open to different interpretations. The Fire Test Study Group and EGOLF have identified a number of such areas and has agreed Resolutions which define common agreement of interpretations between fire test laboratories which are members of the Groups. Where such Resolutions are applicable to this test they have been followed.
- **Instruction to test** The test was conducted on the 14th, 18th & 19th September 2012 at the request of Giza Cables Co. Energya, the sponsor of the test.
- Provision of test
specimensThe specimens were supplied by the sponsor of the test.ExovaWarringtonfire
was not involved in any selection or sampling procedure.
- **Conditioning of** The specimens were received on the 5th September 2012.

Prior to the test the specimens were conditioned for at least 16 hours in an atmosphere having a temperature of $23 \pm 2^{\circ}$ C and a relative humidity of $50 \pm 5\%$.

Document No.: 322002 Author: T. Beny Client: Giza Ca

specimens

322002 T. Benyon Giza Cables Co. Energya Page No.: Issue Date: Issue No.:





Description of Test Specimens

The description of the specimens given below has been prepared from information provided by the sponsor of the test. All values quoted are nominal, unless tolerances are given.

Cable marking		"GIZA CABLES - ELSEWEDY 1 X 300 MM2 0.6 / 1 KV CU/MICA/XLPE/SWA/LSHF 2012"		
Cable function		Electricity power cable		
Number of cores x core size		1x 300mm ²		
Voltage rating		0.6/1KV		
Name of manu	ufacturer	Giza Cables – Elsewedy Energya		
Overall diamet		34.5mm (stated by sponsor)		
		35.8mm (determined by Exova Warringtonfire)		
Overall weight	per unit length	3.55kg/m		
	Product reference	"ENERGYA Metal"		
	Generic type	Copper		
-	Name of manufacturer	ENERGYA Metal		
-	Total cross-sectional area of	300mm ²		
	each conductor			
Conductors	Cross sectional area of each strand	8.6mm ²		
	Weight per unit length per strand	9.32kg/m		
	Number of strands per conductor	37		
	Product reference	"Cogebi"		
Tana	Generic type	Mica tape		
Tape (surrounding -	Name of manufacturer	Cogebi		
each	Colour	"Light Grey"		
conductor)	Thickness	Cogebi		
	Weight per unit length	160g/m ²		
	Flame retardant details	See Note 1 below		
	Product reference	"Borealis"		
	Generic type	Cross linked polyethylene		
Caradulatar	Name of manufacturer	Borealis		
Conductor insulation	Colour	"Grey"		
insulation	Thickness	1.8mm		
	Density	0.93g/cm ³		
[Flame retardant details	See Note 1 below		
	Product reference	"Fainplast"		
	Generic type	LSOH		
		See Note 1 below		
Innor chooth	Name of manufacturer	Fainplast		
Inner sheath	Colour	"Black"		
	Thickness	1.0mm		
	Density	1.46g/cm ³		
	Flame retardant details	See Note 1 below		

Continued on next page

Document No.: 322002 Author: T. Beny

Client:

322002 T. Benyon Giza Cables Co. Energya Page No.: Issue Date: Issue No.:





	Product reference	"Misr For Aluminum"	
Armour	Generic type	Aluminium wires	
	Name of manufacturer	Misr For Aluminum	
	Number of strands	48 wires	
	Cross sectional area of each strand	2.27 mm ²	
	Weight per unit length of each strand	6.13kg/km	
	Product reference	"Fainplast"	
	Generic type	LS0H	
		See Note 1 below	
Outer	Name of manufacturer	Fainplast	
sheath	Colour	"Black"	
	Thickness	1.7mm	
	Density	1.46g/cm ³	
	Flame retardant details	See Note 1 below	
Brief description of manufacturing process		Drawing	
5		• Stranding	
		 Taping (mica + polyester) 	
		Insulation	
		Assembling	
		 Inner sheath (bedding) 	
		Armouring	
		Sheathing	

Note 1: The sponsor of the test was unable to provide this or further information.

Document No.:322002Author:T. BenyClient:Giza Ca

322002 T. Benyon Giza Cables Co. Energya Page No.: Issue Date: Issue No.:





Test Results

Applicability of test results relate only to the behaviour of the specimen of the cable under the particular conditions of test; they are not intended to be the sole criterion for assessing the potential fire hazards of the product in use.

The test results relate only to the specimen of the cable in the form in which it was tested. Small differences in the composition of the product may significantly affect the performance during the test and may therefore invalidate the test results. Care should be taken to ensure that any product, which is supplied or used, is fully represented by the specimen, which was tested.

Results Resistance to fire alone (Section D.2, Category C)

When tested in accordance with the procedures specified in Section D.2 of the standard, for a period of 3 hours at a temperature of 950^oC and a rated voltage of 1000V-rms, the cable maintained its circuit integrity and consequently satisfied the performance requirements specified in BS 6387: 1994.

Resistance to fire with water (Section D.3, Category W)

When tested in accordance with the procedures specified in Section D.3 of the standard, for a period of 30 minutes at a temperature of 650°C and a rated voltage of 1000V-rms, the cable maintained its circuit integrity and consequently satisfied the performance requirements specified in BS 6387: 1994.

Resistance to fire and mechanical shock (Section D.4, Category Z)

When mounted in accordance with the procedure detailed in Annex E.2 of BS 7629: Part 1:1997 and tested in accordance with the procedures specified in Section D.4 of the standard, for a period of 15 minutes at a temperature of 950° C and a rated voltage of 1000V-rms, the cable maintained its circuit integrity and consequently satisfied the performance requirements specified in BS 6387: 1994.

Conclusion When tested in accordance with BS 6387: 1994: Section D.2, D.3 and D.4 the cable meets the criteria for Categories C, W and Z.

It should however, be noted that in the case of the Category Z test the cable was mounted in accordance with the procedure detailed in Annex E.2 of BS 7629: Part 1:1997.

Validity The specification and interpretation of fire test methods are the subject of ongoing development and refinement. Changes in associated legislation may also occur. For these reasons it is recommended that the relevance of test reports over five years old should be considered by the user. The laboratory that issued the report will be able to offer, on behalf of the legal owner, a review of the procedures adopted for a particular test to ensure that they are consistent with current practices, and if required may endorse the test report.

This report may only be reproduced in full. Extracts or abridgements shall not be published without permission of **Exova Warringtonfire**.

Document No.:	322002	Page No.:	8 of 9
Author:	T. Benyon	Issue Date:	4 th October 2012
Client:	Giza Cables Co. Energya	Issue No.:	1





Revision History

Issue No :	Re-issue Date:
Revised By:	Approved By:
Reason for Revision:	
Issue No ·	Re-issue Date:

Issue No :	Re-issue Date:
Revised By:	Approved By:
Reason for Revision:	

Document No.:322002Author:T. BenyClient:Giza Ca

322002 T. Benyon Giza Cables Co. Energya Page No.: Issue Date: Issue No.:

