

KEMA TEST REPORT


1149-20

Object	Single-core power cable		
Type	19/33(36) kV 1x800 mm ² XLPE Cable		
Rated voltage, U₀/U (U_m)	19/33(36) kV	Conductor material	Cu
Conductor cross-section	1x800 mm ²	Insulation material	XLPE
Client	Energya Power Cables – Elsewedy Helal Industrial Zone A, 10th of Ramadan City, Egypt		
Manufacturer	Energya Power Cables – Elsewedy Helal Industrial Zone A, 10th of Ramadan City, Egypt		
Tested by	KEMA B.V., Klingelbeekseweg 195, Arnhem, The Netherlands		
Date of tests	5 March to 7 May 2020		
Test specification	The tests have been carried out in accordance with client's instructions. Test procedure and test parameters were based on IEC 60502-2:2014 and for sheath material ST ₈ IEC 60502-1.		
Summary and conclusion	The object fulfilled the requirements of the performed tests.		

This report applies only to the object tested. The responsibility for conformity of any object having the same type references as that tested rests with the Manufacturer.
*) as declared by the client

This report consists of 40 pages in total.

KEMA B.V.



Bas Verhoeven
Director, High-Voltage
Laboratory

Arnhem, 2 June 2020

INFORMATION SHEET**1 KEMA Type Test Certificate**

A KEMA Type Test Certificate contains a record of a series of (type) tests carried out in accordance with a recognized standard. The object tested has fulfilled the requirements of this standard and the relevant ratings assigned by the manufacturer are endorsed by KEMA Labs. In addition, the object's technical drawings have been verified and the condition of the object after the tests is assessed and recorded. The Certificate contains the essential drawings and a description of the object tested. A KEMA Type Test Certificate signifies that the object meets all the requirements of the named subclauses of the standard. It can be identified by gold-embossed lettering on the cover and a gold seal on its front sheet.

The Certificate is applicable to the object tested only. KEMA Labs is responsible for the validity and the contents of the Certificate. The responsibility for conformity of any object having the same type references as the one tested rests with the manufacturer.

Detailed rules on types of certification are given in KEMA Labs' Certification procedure applicable to KEMA Labs.

2 KEMA Report of Performance

A KEMA Report of Performance is issued when an object has successfully completed and passed a subset (but not all) of test programmes in accordance with a recognized standard. In addition, the object's technical drawings have been verified and the condition of the object after the tests is assessed and recorded. The report is applicable to the object tested only. A KEMA Report of Performance signifies that the object meets the requirements of the named subclauses of the standard. It can be identified by silver-embossed lettering on the cover and a silver seal on its front sheet.

The sentence on the front sheet of a KEMA Report of Performance will state that the tests have been carried out in accordance with The object has complied with the relevant requirements.

3 KEMA Test Report

A KEMA Test Report is issued in all other cases. Reasons for issuing a KEMA Test Report could be:

- Tests were performed according to the client's instructions.
- Tests were performed only partially according to the standard.
- No technical drawings were submitted for verification and/or no assessment of the condition of the object after the tests was performed.
- The object failed one or more of the performed tests.

The KEMA Test Report can be identified by the grey-embossed lettering on the cover and grey seal on its front sheet.

In case the number of tests, the test procedure and the test parameters are based on a recognized standard and related to the ratings assigned by the manufacturer, the following sentence will appear on the front sheet. The tests have been carried out in accordance with the client's instructions. Test procedure and test parameters were based on If the object does not pass the tests such behaviour will be mentioned on the front sheet. Verification of the drawings (if submitted) and assessment of the condition after the tests is only done on client's request.

When the tests, test procedure and/or test parameters are not in accordance with a recognized standard, the front sheet will state the tests have been carried out in accordance with client's instructions.

4 Official and uncontrolled test documents

The official test documents of KEMA Labs are issued in bound form. Uncontrolled copies may be provided as a digital file for convenience of reproduction by the client. The copyright has to be respected at all times.

5 Accreditation of KEMA Laboratories

The KEMA Labs are accredited in accordance with ISO/IEC 17025 by the respective national accreditation bodies. KEMA Labs Arnhem, The Netherlands, is accredited by RvA under nos. L020, L218, K006 and K009. KEMA Labs Chalfont, United States, is accredited by A2LA under no. 0553.01. KEMA Labs Prague, the Czech Republic, is accredited by CAI as testing laboratory no. 1035.

REVISION OVERVIEW

Rev. No	Date of issue	Reason for issue
0	2 June 2020	First issue

TABLE OF CONTENTS

Information sheet.....	2
Revision overview.....	3
Table of contents.....	4
1 Identification of the object tested	6
1.1 Ratings/characteristics of the object tested	6
1.2 Description of the object tested	6
1.3 List of drawings	9
2 General information	10
2.1 The tests were witnessed by	10
2.2 The tests were carried out under responsibility of	10
2.3 Measurement uncertainty	10
2.4 Purpose of test	10
3 Electrical type tests	11
3.1 Test arrangement	11
3.1.1 Determination of the cable conductor temperature	11
3.1.2 Photograph of test set-up	12
3.2 Bending test	13
3.3 Partial discharge test	14
3.4 Tan δ measurement	15
3.5 Heating cycle test	16
3.6 Partial discharge test	17
3.7 Impulse test	18
3.8 Voltage test for 15 min	21
3.9 Voltage test for 4 h	22
3.10 Resistivity of semi-conducting screens	23
4 Non-electrical type tests	24
4.1 Measurement of thickness of insulation	24
4.2 Measurement of thickness of non-metal sheaths (including extruded separation sheaths, but excluding inner coverings)	25
4.3 Tests for determining the mechanical properties of insulation before and after ageing	26
4.4 Tests for determining the mechanical properties of non-metal sheaths before and after ageing	27
4.5 Additional ageing test on pieces of completed cable	28
4.6 Pressure test at high temperature on insulation and non-metal sheaths	30
4.7 Impact test on LSHF sheaths at low temperature	31
4.8 Hot set test for XLPE insulation	32
4.9 Water absorption test on insulation	33
4.10 Flame spread on single cables	34

4.11 Shrinkage test for XLPE insulation 35

4.12 Strippability test for insulation screen 36

5 Check of cable construction.....37

6 Drawings39

7 Measurement uncertainty.....40

1 IDENTIFICATION OF THE OBJECT TESTED

1.1 Ratings/characteristics of the object tested

Rated voltage, U_0/U (U_m)	19/33 (36) kV
Rated maximum conductor temperature in normal operation	90 °C
Rated conductor cross-section	1x800 mm ²

1.2 Description of the object tested

Standard	IEC 60502-2, Clauses 5 to14
Manufacturer	Energya Power Cables – Elsewedy Helal Industrial Zone A, 10 th of Ramadan City, Egypt
Type	19/33 kV 1x800 mm ² Cu/XLPE/CT/AWA/LSHF Cable
Manufacturing year	2019
Quantity submitted	70 m
Rated voltage, U_0/U (U_m)	18 / 30 (36) kV
Nominal capacitance between conductor and metal screen	0,379 μF/km
No. of cores	1
Overall diameter	69,5 mm
Marking on the oversheath	ENERGYA POWER CABLES-ELSEWEDY HELAL ELECTRIC CABLE Cu/XLPE/AWA/LSHF 33000 V 1 X 800 MM2 2019 Meter marking
Construction	see List of drawings
Conductor	
• material	copper
• cross-section	800 mm ²
• nominal diameter	34,4 mm
• type	compacted stranded
• maximum conductor temperature in normal operation	90 °C
• presence and nature of measures to achieve longitudinal water tightness	no
Conductor screen	
• material	semi-conducting PE
• nominal thickness	0,5 mm
• material designation	known in KEMA Labs' files
• manufacturer of the material	known in KEMA Labs' files

Insulation

- material XLPE
- nominal thickness 8,0 mm
- nominal inner diameter of the insulation 36,12 mm
- nominal outer diameter of the insulation 52,12 mm
- material designation known in KEMA Labs' files
- manufacturer of the material known in KEMA Labs' files

Insulation (core) screen

- material semi-conduction PE
- strippable yes
- nominal thickness 0,5 mm
- material designation known in KEMA Labs' files
- manufacturer of the material known in KEMA Labs' files

Metal screen

- material copper tape
- number of tapes one
- thickness and width of tapes 0,075 x 40 mm (overlap: 10%) (approx.)
- cross-sectional area 8 mm² (approx.)

Separation sheath

- material LSHF – inner covering
- nominal thickness 1,6 mm
- manufacturer of the material known in KEMA Labs' files

Metal armour

- material aluminium wires
- number of wires 70
- nominal diameter of wires 2,5mm ± 5%
- manufacturer of the material known in KEMA Labs' files

Oversheath

- material LSHF type ST₈
- nominal thickness 2,5 mm (minimum)
- nominal overall diameter of the cable (D) 69,5 mm (approx.)
- material designation LSHF-ST₈
- manufacturer of the material known in KEMA Labs' files
- colour black

Fire retardant (according to IEC 60332-1) yes

Manufacturing details insulation system

- location of manufacturing Industrial Zone A, 10th of Ramadan City, Egypt
- type of extrusion line CCV
- type of extrusion triple common extrusion
- factory identification of extrusion line CCV1
- manufacturer of the extrusion line known in KEMA Labs' files
- identification of production batch 249/19
- curing means dry
- cooling means water
- manufacturing length (where cable sample for testing has been taken from) 300 m
- length markings on cable sample sent to KEMA Labs begin: 005 m, end: 070m

1.3 List of drawings

The manufacturer has guaranteed that the object submitted for tests has been manufactured in accordance with the following drawings and/or documents. KEMA Labs has verified that these drawings and/or documents adequately represent the object tested. The manufacturer is responsible for the correctness of these drawings and/or documents and the technical data presented.

The following drawings and/or documents have been included in this report

Drawing no./document no.	Revision
CT70X501XL	2

2 GENERAL INFORMATION

2.1 The tests were witnessed by

The tests were carried out without a representative of the client present.

2.2 The tests were carried out under responsibility of

Name	Company
A. Kumar	KEMA B.V.,
H. van Zuilen	Arnhem, The Netherlands
S. van der Weiden	

2.3 Measurement uncertainty

A table with measurement uncertainties is enclosed in this report. Unless otherwise stated, the measurement uncertainties of the results presented in this report are as indicated in that table.

2.4 Purpose of test

Purpose of the test was to verify whether the material complies with the specified requirements.

3 ELECTRICAL TYPE TESTS

3.1 Test arrangement

3.1.1 Determination of the cable conductor temperature

Standard

Standard IEC 60502-2, subclause 15.4

For the tests at elevated temperature, a reference loop for temperature control of the conductor was installed and conductor current was used for heating. The reference cable was cut from the total cable length intended for the type test. This reference loop was installed close to the test loop in order to create the same environmental conditions as for the test loop.

The heating currents in the reference loop and the test loop were kept equal at all times, thus the conductor temperature of the reference loop is representative for the conductor temperature of the test loop. Annex G was used as a guide and Annex G, subclause G.3.1, method 1 was applied.

The tests at elevated temperature are carried out after the conductor temperature has been within the stated limit for at least 2 hours.

3.1.2 Photograph of test set-up



3.2 Bending test

Standard and date

Standard IEC 60502-2, subclause 18.2.4

Test date 5 March 2020

Environmental conditions

Ambient temperature 8 °C

Characteristic test data

Temperature of test object 8 °C

Maximum bending diameter $20(d + D) + 5\%$

Length of cable bended 21 m

Actual external diameter of cable D mm	Actual diameter of cable conductor d mm	Maximum bending diameter D_r mm	Diameter of test cylinder D_t mm
77,5	34,4	≤ 2350	1560

Result

The test was carried out successfully.

3.3 Partial discharge test

Standard and date

Standard IEC 60502-2, subclause 18.2.5
 Test date 10 March 2020

Environmental conditions

Ambient temperature 20 °C

Characteristic test data

Temperature of test object 20 °C
 Circuit direct
 Calibration 10 pC
 Noise level at 1,73 U₀ 2,5 pC
 Declared sensitivity 5 pC
 Required sensitivity ≤ 5 pC
 Centre frequency 100 kHz
 Bandwidth (Δf) 100 kHz
 Test frequency 50 Hz
 Coupling capacitor 2,6 nF

Core	Voltage applied, 50 Hz		Duration s	Partial discharge level pC
	... x U ₀	kV		
1	2	38	10	-
	1,73	33	-	Not detectable

Requirement

There shall be no detectable discharge exceeding the declared sensitivity from the test object at 1,73 U₀.

Result

The object passed the test.

3.4 Tan δ measurement

Standard and date

Standard IEC 60502-2, subclause 18.2.6

Test date 12 March 2020

Environmental conditions

Ambient temperature 20 °C

Characteristic test data

Temperature of test object 97 °C

Length of test object 17,41 m

Standard capacitor 99,918 pF

Core	Voltage applied, 50 Hz kV	Capacitance of core ¹⁾ $\mu\text{F}/\text{km}$	Tan δ
1	5	0,30	$1,2 \times 10^{-4}$
¹⁾ for information only			

RequirementThe measured value shall not be higher than 40×10^{-4} at ≥ 2 kV.**Result**

The object passed the test.

3.5 Heating cycle test

Standard and date

Standard IEC 60502-2, subclause 18.2.7

Test date 13 to 23 March 2020

Environmental conditions

Ambient temperature 20 °C

Characteristic test data

Heating method conductor current

No. of heating cycles	Steady conductor temperature °C	Heating current during steady condition A	Heating cycle		
			Heating		Cooling
			Total duration h	Duration of conductor at steady temperature h	Total duration h
20	97	approx. 1895	5	2	5

Requirement

The test shall be carried out successfully.

Result

The object passed the test.

3.6 Partial discharge test

Standard and date

Standard IEC 60502-2, subclause 18.2.5
 Test date 23 March 2020

Environmental conditions

Ambient temperature 20 °C

Characteristic test data

Temperature of test object 29 °C
 Circuit direct
 Calibration 10 pC
 Noise level at 1,73 U₀ 3 pC
 Declared sensitivity 5 pC
 Required sensitivity ≤ 5 pC
 Centre frequency 125,5 kHz
 Bandwidth (Δf) 100 kHz
 Test frequency 50 Hz
 Coupling capacitor 2,6 nF

Core	Voltage applied, 50 Hz		Duration s	Partial discharge level pC
	... x U ₀	kV		
1	2	38	10	-
	1,73	33	-	Not detectable

Requirement

There shall be no detectable discharge exceeding the declared sensitivity from the test object at 1,73 U₀.

Result

The object passed the test.

3.7 Impulse test

Standard and date

Standard IEC 60502-2, subclause 18.2.8
 Test date 24 March 2020

Environmental conditions

Ambient temperature 20 °C

Characteristic test data

Temperature of test object 98 °C
 Specified test voltage 170 kV (test was performed at 194 kV)

Testing arrangement		Polarity	Voltage applied (% of test voltage)	No. of impulses	See figure on next pages
Voltage applied to	Earthed				
Conductor	Metal screen	Positive	50	1	1 (waveshape)
			65	1	2
			80	1	2
			100	10	3 and 4
Conductor	Metal screen	Negative	50	1	5 (waveshape)
			65	1	6
			80	1	6
			100	10	7 and 8

Requirement

The cable core shall withstand without failure 10 positive and 10 negative voltage impulses.

Result

The object passed the test.

Lightning impulse test with positive voltage




Fig. 1: Waveshape 72220708 1X 800 mm² Energya Cable RFW 50% (+)




Fig. 2: 72220708 1X 800 mm² Energya Cable RFW 65% and 80% (+)




Fig. 3: 72220708 1X 800 mm² Energya Cable FW 100% (+)




Fig. 4: 72220708 1X 800 mm² Energya Cable FW 100% (+)

Lightning impulse test with negative voltage




Fig. 5: Waveshape 72220708 1X 800 mm² Energia Cable RFW 50% (-)




Fig. 6: 72220708 1X 800 mm² Energia Cable RFW 65% and 80% (-)




Fig. 7: 72220708 1X 800 mm² Energia Cable FW 100% (-)




Fig. 8: 72220708 1X 800 mm² Energia Cable FW 100% (-)

3.8 Voltage test for 15 min

Standard and date

Standard IEC 60502-2, subclause 18.2.8

Test date 25 March 2020

Environmental conditions

Ambient temperature 20 °C

Characteristic test data

Temperature of test object 20 °C

Testing arrangement		Voltage applied, 50 Hz		Duration min
Voltage applied to	Earth connected to	... x U ₀	kV	
Conductor	Metal screen	3,5	66,5	15

Requirement

No breakdown of the insulation shall occur.

Result

The object passed the test.

3.9 Voltage test for 4 h

Standard and date

Standard IEC 60502-2, subclause 18.2.9
Test date 25 March 2020

Environmental conditions

Ambient temperature 20 °C

Characteristic test data

Temperature of test object 20 °C

Testing arrangement		Voltage applied, 50 Hz		Duration
Voltage applied to	Earth connected to	... x U ₀	kV	h
Conductor	Metal screen	4	76	4

Requirement

No breakdown of the insulation shall occur.

Result

The object passed the test.

3.10 Resistivity of semi-conducting screens

Standard and date

Standard IEC 60502-2, subclause 18.2.10

Test date 1 May 2020

Characteristic test data

Temperature during ageing 100 °C

Duration 7 x 24 h (19 March to 26 March 2020)

Resistivity measured at 90 ± 2 °C

Item	Unit	Requirement	Measured/determined
Conductor screen			
without ageing	Ωm	≤ 1000	4
after ageing	Ωm	≤ 1000	13
Insulation screen			
without ageing	Ωm	≤ 500	2
after ageing	Ωm	≤ 500	2

Result

The object passed the test.

4 NON-ELECTRICAL TYPE TESTS

4.1 Measurement of thickness of insulation

Standard and date

Standard IEC 60502-2, subclause 19.2

Test date 7 April 2020

Item	Unit	Requirement	Specified	Measured/determined
Nominal	mm	8	8	-
Average	mm	-	-	9,37
Minimum [t_{min}]	mm	$\geq 7,10$	-	9,16
Maximum [t_{max}]	mm	-	-	9,71
$(t_{max} - t_{min}) / t_{max}$	-	$\leq 0,15$	-	0,06

Result

The object passed the test.

4.2 Measurement of thickness of non-metal sheaths (including extruded separation sheaths, but excluding inner coverings)

Standard and date

Standard IEC 60502-1, subclause 16.5.2

Test date 7 May 2020

Separation sheath

Item	Unit	Requirement	Specified	Measured/determined
Nominal	mm	-	1,6	-
Average	mm	-	-	2,53
Minimum	mm	≥ 1,08	-	2,36

Oversheath

Item	Unit	Requirement	Specified	Measured/determined
Nominal	mm	≥ 1,4	3,4	-
Average	mm	-	-	3,87
Minimum	mm	≥ 2,50	-	3,70

Note

The nominal thickness of the separation sheath and oversheath is calculated according to Subclause 13.3.3 and Annex A.}

The requirements of sheath material ST₈ according to IEC 60502-1. ST₈ is not covered by IEC 60502-2.

Result

The object passed the test

4.3 Tests for determining the mechanical properties of insulation before and after ageing

Standard and date

Standard IEC 60502-2, subclause 19.5

Test date 31 March 2020

Characteristic test data

Temperature during ageing $135 \pm 3 \text{ }^\circ\text{C}$

Ageing duration 7 x 24 h (27 March to 03 April 2020)

Item	Unit	Requirement	Measured/determined
Without ageing			
Tensile strength	N/mm ²	≥ 12,5	27,2
Elongation at break	%	≥ 200	592
After ageing in air oven			
Tensile strength			
• value after ageing	N/mm ²	-	30,8
• variation	%	± 25 max.	13
Elongation at break			
• value after ageing	%	-	607
• variation	%	± 25 max.	2

Result

The object passed the test.

4.4 Tests for determining the mechanical properties of non-metal sheaths before and after ageing

Standard and date

Standard IEC 60502-1, subclause 18.5.4
 Test date 1 April 2020

Characteristic test data (below values based on ST₈)

Temperature during ageing 100 ± 2 °C
 Ageing duration 7 x 24 h (27 March to 3 April 2020)

Separation sheath*

Item	Unit	Requirement	Measured/determined
Without ageing			
Tensile strength	N/mm ²	≥ 9	12,3
Elongation at break	%	≥ 125	147
After ageing in air oven			
Tensile strength			
• value after ageing	N/mm ²	≥ 9	14,4
• variation	%	± 40	17
Elongation at break			
• value after ageing	%	≥ 100	146
• variation	%	± 40	-1

Oversheath*

Item	Unit	Requirement	Measured/determined
Without ageing			
Tensile strength	N/mm ²	≥ 9	13,0
Elongation at break	%	≥ 125	159
After ageing in air oven			
Tensile strength			
• value after ageing	N/mm ²	≥ 9	14,0
• variation	%	± 40	8
Elongation at break			
• value after ageing	%	≥ 100	132
• variation	%	± 40	-17

Note

Sheath material ST₈ is not covered by IEC 60502-2. The requirements of sheath material ST₈ according to IEC 60502-1.

Result

The object passed the test

4.5 Additional ageing test on pieces of completed cable

Standard and date

Standard IEC 60502-2, subclause 19.7 and IEC 60502-1, subclause 18.3
 Test date 31 March 2020

Characteristic test data

Temperature during ageing $100 \pm 2 \text{ }^\circ\text{C}$
 Ageing duration 7 x 24 h (19 March to 26 March 2020)

Insulation

Item	Unit	Requirement	Measured/determined
Without ageing			
Tensile strength	N/mm ²	≥ 12,5	27,2
Elongation at break	%	≥ 200	592
After ageing in air oven			
Tensile strength			
• value after ageing	N/mm ²	-	29,9
• variation	%	± 25 max.	10
Elongation at break			
• value after ageing	%	-	550
• variation	%	± 25 max.	-7

Separation sheath

Item	Unit	Requirement	Measured/determined
Without ageing			
Tensile strength	N/mm ²	≥ 9	12,3
Elongation at break	%	≥ 125	147
After ageing in air oven			
Tensile strength			
• value after ageing	N/mm ²	≥ 9	15,8
• variation	%	± 40	28
Elongation at break			
• value after ageing	%	≥ 100	190
• variation	%	± 40	30

Oversheath

Item	Unit	Requirement	Measured/determined
Without ageing			
Tensile strength	N/mm ²	≥ 9	13,0
Elongation at break	%	≥ 125	159
After ageing in air oven			
Tensile strength			
• value after ageing	N/mm ²	≥ 9	16,6
• variation	%	± 40	28
Elongation at break			
• value after ageing	%	≥ 100	166
• variation	%	± 40	4

Note

Sheath material ST₈ is not covered by IEC 60502-2. The requirements of sheath material ST₈ according to IEC 60502-1.

Result

The object passed the test.

4.6 Pressure test at high temperature on insulation and non-metal sheaths

Standard and date

Standard IEC 60502-1, subclause 18.7
 Test date 15 April 2020

Characteristic test data

Temperature $80 \pm 2 \text{ }^\circ\text{C}$
 Heating time 6 h
 Load 12 N

Separation sheath

Item	Unit	Requirement	Measured/determined
Depth of indentation	%	≤ 50	7

Characteristic test data

Temperature $80 \pm 2 \text{ }^\circ\text{C}$
 Heating time 6 h
 Load 16 N

Oversheath

Item	Unit	Requirement	Measured/determined
Depth of indentation	%	≤ 50	17

Note

Sheath material ST₈ is not covered by IEC 60502-2. The requirements of sheath material ST₈ according to IEC 60502-1.

Result

The object passed the test.

4.7 Impact test on LSHF sheath at low temperature

Standard and date

Standard IEC 60502-1, subclause 18.8

Test date 10 April 2020

Characteristic test dataTemperature $-15 \pm 2 \text{ }^\circ\text{C}$ Cooling time $\geq 16 \text{ h}$

Mass of hammer 1250 g

Separation sheath

Item	Unit	Requirement	Measured/determined
Cold elongation test	%	≥ 20	50
Cold impact test	-	No cracks	No cracks

Characteristic test dataTemperature $-15 \pm 2 \text{ }^\circ\text{C}$ Cooling time $\geq 16 \text{ h}$

Mass of hammer 1500 g

Oversheath

Item	Unit	Requirement	Measured/determined
Cold elongation test	%	≥ 20	43
Cold impact test	-	No cracks	No cracks

Result

The object passed the test.

4.8 Hot set test for XLPE insulation

Standard and date

Standard IEC 60502-2, subclause 19.13

Test date 26 March 2020

Characteristic test data

Air temperature $200 \pm 3 \text{ }^\circ\text{C}$

Time under load 15 min

Mechanical stress 20 N/cm^2

Insulation

Item	Unit	Requirement	Measured/determined
Elongation under load	%	≤ 175	50
Permanent elongation after cooling	%	≤ 15	-5

Result

The object passed the test.

4.9 Water absorption test on insulation

Standard and date

Standard IEC 60502-2, subclause 19.15

Test date 24 March to 13 April 2020

Characteristic test data

Temperature of water $85 \pm 2 \text{ }^\circ\text{C}$

Duration 14 x 24 h

Test method Gravimetric

Insulation

Item	Unit	Requirement	Measured/determined
Increase of mass	mg/cm ²	< 1	0,1

Result

The object passed the test.

4.10 Flame spread on single cables

Standard and date

Standard IEC 60502-2, subclause 19.16

Test date 21 April 2020

Characteristic test data

Overall diameter of test piece 77,3 mm

Time for flame application 480 s

Flame type 1 kW pre-mixed flame

Complete cable	Unit	Requirement	Measured/determined
The distance between the lower edge of the top support and the onset of charring	mm	≥ 50	395
The distance between the lower edge of the top support and charring extends downwards to a point	mm	≤ 540	510

Result

The object passed the test.

4.11 Shrinkage test for XLPE insulation

Standard and date

Standard IEC 60502-2, subclause 19.18

Test date 17 April 2020

Characteristic test data

Distance L between marks 200 mm

Temperature 130 ± 3 °C

Duration 1 h

Insulation

Item	Unit	Requirement	Measured/determined
Shrinkage	%	≤ 4	2,7

Result

The object passed the test.

4.12 Strippability test for insulation screen

Standard and date

Standard IEC 60502-2, subclause 19.23

Test date 23 April 2020

Characteristic test data

Temperature $100 \pm 2 \text{ }^\circ\text{C}$

Ageing duration 7 x 24 h

Sample 1

Item	Unit	Requirement	Measured/Determined
Before ageing	N	$4 \leq F \leq 45$	$36,5 \leq F \leq 38,6$
After ageing	N	$4 \leq F \leq 45$	$22,6 \leq F \leq 25,6$

Sample 2

Item	Unit	Requirement	Measured/Determined
Before ageing	N	$4 \leq F \leq 45$	$38,4 \leq F \leq 40,2$
After ageing	N	$4 \leq F \leq 45$	$29,4 \leq F \leq 31,2$

Sample 3

Item	Unit	Requirement	Measured/Determined
Before ageing	N	$4 \leq F \leq 45$	$37,0 \leq F \leq 38,0$
After ageing	N	$4 \leq F \leq 45$	$27,5 \leq F \leq 29,7$

Result

The object passed the test.

5 CHECK OF CABLE CONSTRUCTION

Standard and date

Standard IEC 60502-2, Clauses 5 to 14

Test date 7 May 2020

Item	Unit	Requirement	Specified	Measured/determined
Conductor				
Diameter of conductor (d)	mm	-	34,4 ± 0,4	34,9 ¹⁾
Number of wires	-	≥ 53	-	61
Diameter of wires	mm	-	-	3,68-4,41 (after compacting)
Swelling yarns applied	-	-	-	no
Resistance at 20 °C	Ω/km	≤ 0,0221	-	0,0212
Semi-conducting tape				
Number of tapes	-	-	-	1
Width	mm	-	-	cannot be determined
Thickness	mm	-	-	0,35 (total thickness)
Overlap	mm	-	-	21 mm
Conductor screen				
Diameter over conductor screen	mm	-	-	37,54
Thickness	mm	-	0,5	1,07
Insulation				
Diameter over insulation	mm	-	-	56,38
Thickness	mm	7,10	8	9,37
Insulation screen				
Diameter over insulation screen	mm	-	-	58,94
Thickness	mm	-	0,5	1,25
Copper screen				
Thickness x width of tape	mm	-	0,075 x 40, 10% overlap	0,094 x 49 (10% overlap, approx.)
Separation sheath				
Diameter over sheath	mm	-	-	64,21
Thickness	mm	≥ 1,2	1,6	2,53
Aluminium wires armour				
Number of wires	-	-	70	74
Thickness	mm	-	2,5 ± 5%	2,58

Item	Unit	Requirement	Specified	Measured/determined
Binder tape over armour				
Number of tapes			-	1
Width and thickness	mm	-	-	40 x 0,1
Overlap	%	-	-	50
Total thickness	mm	-	-	0,38 (total thickness)
Oversheath				
Diameter over oversheath	mm	-	69,5	77,33
Thickness	mm	-	2,5	3,87
Colour	-	-	black	black

Marking on the cable	Line 1: ENERGYA POWER CABLES-ELSEWEDY HELAL ELECTRIC CABLE Cu/XLPE/AWA/LSHF 33000 V BS 7835 1 X 800 MM2 2019 Meter marking Line 2: ELECTRIC CABLE 33000 V BS 7835
----------------------	--

¹⁾Dimensional limits do not have the statues of a requirement but as a guideline only

Result

The object passed the test.

6 DRAWING

Size : 1 x 800 mm ²		Type : CU/XLPE/CT/AWA/LSHF	
Item Code : CT70X501XL			
Voltage: 19/33 kV		Standard: IEC 60502-2	
Sr.	Description	Thickness mm	Diameter (Approx.) Mm
1.	Compacted Circular Copper		34.4 ± 0.4
2.	Binder Tape	Applicable	
3.	Inner Semi-Conductive	0.5 (Nominal)	
4.	XLPE Insulation	8 (Nominal)	
5.	Outer Semi-Conductive (Strippable)	0.5 (Nominal)	
6.	Copper Tape Screen with 10% overlap	0.075 (Nominal)	
7.	LSHF Bedding	1.08 (Minimum)	
8.	Aluminum Wires Armour	2.5 ± 5%	
9.	Binder Tape	Applicable	
10.	LSHF Sheath	2.5 (Minimum)	
Not to Scale			
Prepared By		Eng. Mohamed Abdel Sattar	

Sunday, 17 May, 2020 Issue 2 Technical Offer No. 1X800 MM2 18/30KV

7 MEASUREMENT UNCERTAINTY

The measurement uncertainties in the results presented are as specified below unless otherwise indicated.

Measurement	Measurement uncertainty
Dielectric tests and impulse current tests:	
peak value	≤ 3%
time parameters	≤ 10%
Capacitance measurement	0,3%
Tan δ measurement	± 0,5% ± 5 x 10 ⁻⁵
Partial discharge measurement:	
< 10 pC	2 pC
10 to 100 pC	5 pC
> 100 pC	20%
Measurement of impedance AC-resistance measurement	≤ 1%
Measurement of losses	≤ 1%
Measurement of insulation resistance	≤ 10%
Measurement of DC resistance:	
1 to 5 μΩ	1%
5 to 10 μΩ	0,5%
10 to 200 μΩ	0,2%
Radio interference test	2 dB
Calibration of current transformers	2,2 x 10 ⁻⁴ I _i /I _u and 290 μrad
Calibration of voltage transformers	1,6 x 10 ⁻⁴ U _i /U _u and 510 μrad
Measurement of conductivity	5%
Measurement of temperature:	
-50 to -40 °C	3 K
-40 to 125 °C	2 K
125 to 150 °C	3 K
Tensile test	1%
Sound level measurement	type 1 meter as per IEC 60651 and ANSI S1,4,1971
Measurement of voltage ratio	0,1%