

# KEMA TYPE TEST CERTIFICATE OF COMPLETE TYPE TESTS

Object Single-core power cable 1143-20

**Type** 19/33(36) kV 1x800 mm<sup>2</sup> XLPE Cable

Rated voltage,  $U_0/U$  ( $U_m$ ) 19/33(36) kV Conductor material Cu Conductor cross-section 1x800 mm<sup>2</sup> Insulation material XLPE

Manufacturer Energya Power Cables – Elsewedy Helal

Industrial Zone A, 10th of Ramadan City, Egypt \*)

Client Energya Power Cables – Elsewedy Helal

45/1

Industrial Zone A, 10th of Ramadan City, Egypt

Tested by KEMA B.V.,

Klingelbeekseweg 195, Arnhem, The Netherlands

Date of tests 5 March to 1 June 2020

The test object, constructed in accordance with the description, drawings and photographs incorporated in this certificate has been subjected to the series of proving tests in accordance with

#### BS 7835:2007

The results are shown in the record of Proving Tests and the oscillograms attached hereto. The values obtained and the general performance are considered to comply with the above Standard(s) and to justify the ratings assigned by the manufacturer as listed on page 6

This Certificate applies only to the object tested. The responsibility for conformity of any object having the same type references as that tested rests with the Manufacturer.

\*) as declared by the manufacturer

This Certificate consists of 59 pages in total.

Bas Verhoeven Director, High-Voltage Laboratory

KEMA B.V

Arnhem, 13 July 2020

-2- 1143-20

#### **INFORMATION SHEET**

#### 1 KEMA Type Test Certificate

A KEMA Type Test Certificate contains a record of a series of (type) tests carried out in accordance with a recognized standard. The object tested has fulfilled the requirements of this standard and the relevant ratings assigned by the manufacturer are endorsed by KEMA Labs. In addition, the object's technical drawings have been verified and the condition of the object after the tests is assessed and recorded. The Certificate contains the essential drawings and a description of the object tested. A KEMA Type Test Certificate signifies that the object meets all the requirements of the named subclauses of the standard. It can be identified by gold-embossed lettering on the cover and a gold seal on its front sheet. The Certificate is applicable to the object tested only. KEMA Labs is responsible for the validity and the contents of the Certificate. The responsibility for conformity of any object having the same type references as the one tested rests with the manufacturer.

Detailed rules on types of certification are given in KEMA Labs' Certification procedure applicable to KEMA Labs.

#### 2 KEMA Report of Performance

A KEMA Report of Performance is issued when an object has successfully completed and passed a subset (but not all) of test programmes in accordance with a recognized standard. In addition, the object's technical drawings have been verified and the condition of the object after the tests is assessed and recorded. The report is applicable to the object tested only. A KEMA Report of Performance signifies that the object meets the requirements of the named subclauses of the standard. It can be identified by silverembossed lettering on the cover and a silver seal on its front sheet.

The sentence on the front sheet of a KEMA Report of Performance will state that the tests have been carried out in accordance with ...... The object has complied with the relevant requirements.

#### 3 KEMA Test Report

A KEMA Test Report is issued in all other cases. Reasons for issuing a KEMA Test Report could be:

- Tests were performed according to the client's instructions.
- Tests were performed only partially according to the standard.
- No technical drawings were submitted for verification and/or no assessment of the condition of the object after the tests was performed.
- The object failed one or more of the performed tests.

The KEMA Test Report can be identified by the grey-embossed lettering on the cover and grey seal on its front sheet.

In case the number of tests, the test procedure and the test parameters are based on a recognized standard and related to the ratings assigned by the manufacturer, the following sentence will appear on the front sheet. The tests have been carried out in accordance with the client's instructions. Test procedure and test parameters were based on ..... If the object does not pass the tests such behaviour will be mentioned on the front sheet. Verification of the drawings (if submitted) and assessment of the condition after the tests is only done on client's request.

When the tests, test procedure and/or test parameters are not in accordance with a recognized standard, the front sheet will state the tests have been carried out in accordance with client's instructions.

#### 4 Official and uncontrolled test documents

The official test documents of KEMA Labs are issued in bound form. Uncontrolled copies may be provided as a digital file for convenience of reproduction by the client. The copyright has to be respected at all times.

#### 5 Accreditation of KEMA Laboratories

The KEMA Labs are accredited in accordance with ISO/IEC 17025 by the respective national accreditation bodies. KEMA Labs Arnhem, The Netherlands, is accredited by RvA under nos. L020, L218, K006 and K009. KEMA Labs Chalfont, United States, is accredited by A2LA under no. 0553.01. KEMA Labs Prague, the Czech Republic, is accredited by CAI as testing laboratory no. 1035.



-3- 1143-20

# **REVISION OVERVIEW**

Rev. No	Date of issue	Reason for issue
0	13 July 2020	First issue





# **TABLE OF CONTENTS**

Inform	ation sheet	2
Revisio	on overview	3
Table o	of contents	4
1	Identification of the object tested	6
1.1	Ratings/characteristics of the object tested	6
1.2	Description of the object tested	6
1.3	Description of the object subjected to the adherence of screens test	8
1.4	List of drawings	9
2	General information	10
2.1	The tests were witnessed by	10
2.2	The tests were carried out under responsibility of	10
2.3	Subcontracting	10
2.4	Measurement uncertainty	10
3	Electrical type tests	11
3.1	Test arrangement	11
3.1.1	Determination of the cable conductor temperature	11
3.1.2	Photograph of test set-up	12
3.2	Bending test	13
3.3	Partial discharge test	14
3.4	Tan $\delta$ in relation to voltage	15
3.5	Tan $\delta$ in relation to temperature	16
3.6	Heating cycle test including partial discharge measurements	17
3.6.1	Heating cycle test	17
3.6.2	Partial discharge during and after heating cycle test	18
3.6.2.1	,	18
3.6.2.2	,	19
3.6.2.3 3.6.2.4	•	20 21
3.7	Impulse test	22
3.8	Four-hour voltage test	25
3.9	Adherence of screens at short circuit temperature	26
3.9.1	Partial Discharge test subjected before short circuit current test	26
3.9.2	Thermal Short-circuit test	27
3.9.2.1		27
3.9.2.2	Test circuit S01	28
3.9.2.3	<b>5</b> .	29
3.9.2.4	•	30
3.9.2.5	•	32
3.9.2.6	Photograph after test	33

-4-



1143-20
_

3.9.3	Partial Discharge subjected after short circuit current test	34
4	Materials – Type test	35
4.1	Resistivity of semi-conducting screens	35
4.2	Measurement of thickness of insulation	36
4.3	Measurement of thickness of non-metal sheaths (including extruded separation sheaths, excluding inner coverings)	, but 37
4.4	Tests for determining the mechanical properties of insulation before and after ageing	38
4.5	Water immersion test	39
4.6	Measurement for aluminium wires	40
4.7	Tests for determining the mechanical properties of non-metal sheaths before and after a	igeing41
4.8	Compatibility test	42
4.9	Pressure test at high temperature on oversheath material	44
4.10	Test for tear resistance	45
4.11	Shrinkage test on oversheaths	46
4.12	Test on PVC insulation and sheaths at low temperature	47
4.13	Hot set test for XLPE insulation	48
4.14	Water absorption test on insulation	49
4.15	Flame spread on single cables	50
4.16	Flame propagation on multiple cables	51
4.17	Smoke emission test	52
4.18	Corrosive and acid gas	53
4.19	Cold strippability	54
4.20	Abrasion test	55
5	Check of cable construction	56
6	Drawing	58
7	Measurement uncertainty	59



-6- 1143-20

#### 1 IDENTIFICATION OF THE OBJECT TESTED

#### 1.1 Ratings/characteristics of the object tested

Rated voltage,  $U_0/U$  ( $U_m$ ) 19/33 (36) kV Rated maximum conductor temperature in normal operation 90 °C Rated conductor cross-section 1x800 mm<sup>2</sup>

# 1.2 Description of the object tested

Standard BS 7835

Manufacturer Energya Power Cables – Elsewedy Helal

Industrial Zone A, 10th of Ramadan City, Egypt

Type 19/33 kV 1x800 mm<sup>2</sup> Cu/XLPE/CT/AWA/LSHF Cable

Manufacturing year 2019

Quantity submitted 70 m

Rated voltage,  $U_0/U$  ( $U_m$ ) 19/33 (36) kV Nominal capacitance between conductor and 0,379  $\mu$ F/km

metal screen

No. of cores 1

Overall diameter 69,5 mm

Marking on the oversheath ENERGYA POWER CABLES-ELSEWEDY HELAL ELECTRIC

90 °C

CABLE Cu/XLPE/AWA/LSHF 33000 V BS 7835 1 X 800

MM2 2019 Meter marking

Line 2 ELECTRIC CABLE 33000 V BS 7835

Construction see List of drawings

#### Conductor

material copper
 cross-section 800 mm<sup>2</sup>
 nominal diameter 34.4 mm

type compacted stranded

maximum conductor temperature in

normal operation

presence and nature of measures to no

achieve longitudinal water tightness

# Conductor screen

material semi-conducting PE

nominal thickness 0,5 mm

material designation
 manufacturer of the material
 known in KEMA Labs' files
 known in KEMA Labs' files



-7- 1143-20

#### Insulation

material XLPE
 nominal thickness 8 mm
 nominal inner diameter of the insulation 36,12 mm
 nominal outer diameter of the insulation 52,12 mm

material designation
 manufacturer of the material
 known in KEMA Labs' files
 known in KEMA Labs' files

#### Insulation (core) screen

• material semi-conduction PE

strippable yesnominal thickness 0,5 mm

material designation
 manufacturer of the material
 known in KEMA Labs' files
 known in KEMA Labs' files

#### Metal screen

material copper tape

number of tapes one

nominal thickness and width of tape
 0,075 x 40 mm (overlap: 10%) (approx.)

• cross-sectional area 8 mm<sup>2</sup> (approx.)

#### **Separation sheath**

material LSHF – inner covering
 nominal thickness 1,08 mm (min.)

manufacturer of the material known in KEMA Labs' files

#### Metal armour

material aluminium wires

number of wires 70

• nominal diameter of wires 2,5mm ± 5%

manufacturer of the material known in KEMA Labs' files

#### Oversheath

(D)

• material LSHF – LTS1

nominal thickness
 nominal overall diameter of the cable
 69,5 mm (approx.)

material designation
 LSHF-LTS1

manufacturer of the material known in KEMA Labs' files

colour black

graphite coating applied no

Fire retardant (according to IEC 60332-1) yes



-8- 1143-20

#### Manufacturing details insulation system

location of manufacturing
 Industrial Zone A, 10<sup>th</sup> of Ramadan City, Egypt

type of extrusion line CC

• type of extrusion triple common extrusion

factory identification of extrusion line CCV1

manufacturer of the extrusion line known in KEMA Labs' files

identification of production batch
 curing means
 cooling means
 water

manufacturing length (where cable
 300 m

sample for testing has been taken from)
length markings on cable sample sent begin: 005m, end: 070m

to KEMA Labs

# 1.3 Description of the object subjected to the adherence of screens test

Voltage 19/33 kV Number of cores 1 Frequency 50 Hz

Conductor:

Material copper
 Cross-section 185 mm²
 Maximum rated temperature 250 °C
 Insulation material XLPE

Metallic screen:

• Material copper tape

• Cross-section 5 mm<sup>2</sup>

Armouring aluminium wires



-9- 1143-20

# 1.4 List of drawings

The manufacturer has guaranteed that the object submitted for tests has been manufactured in accordance with the following drawings and/or documents. KEMA Labs has verified that these drawings and/or documents adequately represent the object tested. The manufacturer is responsible for the correctness of these drawings and/or documents and the technical data presented.

The following drawings and/or documents have been included in this Certificate Drawing no./document no. Revision CT70X501XL 2





#### **2 GENERAL INFORMATION**

# 2.1 The tests were witnessed by

The tests were carried out without a representative of the client present.

# 2.2 The tests were carried out under responsibility of

Name Company
A.Kumar KEMA B.V.,
H.van Zuilen Arnhem, The Netherlands
S.van der Weiden
D.Minkhorst

# 2.3 Subcontracting

The following tests were subcontracted to BRE Global United Kingdom and ISQ Portugal

- flame propagation on multiple cables 4,16 subclause 20.15
- smoke emission test 4,17 subclause 20.16
- corrosive and acid gas 4,18 subclause 20.2 (ISQ Portugal).

# 2.4 Measurement uncertainty

A table with measurement uncertainties is enclosed in this Certificate. Unless otherwise stated, the measurement uncertainties of the results presented in this Certificate are as indicated in that table.



-11- 1143-20

#### 3 ELECTRICAL TYPE TESTS

# 3.1 Test arrangement

#### 3.1.1 Determination of the cable conductor temperature

#### **Standard**

Standard BS EN 61442

For the tests at elevated temperature, a reference loop for temperature control of the conductor was installed and conductor current was used for heating. The reference cable was cut from the total cable length intended for the type test. This reference loop was installed close to the test loop in order to create the same environmental conditions as for the test loop.

The heating currents in the reference loop and the test loop were kept equal at all times, thus the conductor temperature of the reference loop is representative for the conductor temperature of the test loop.

The tests at elevated temperature are carried out after the conductor temperature has been within the stated limit for at least 2 hours. All single phases of both the reference loop and the test loop carried the same level single-phase current. Annex A, method 1 of IEC 60840 was used as a guide.





# 3.1.2 Photograph of test set-up





-13- 1143-20

# 3.2 Bending test

#### Standard and date

Standard BS 7835, subclause 21.3

Test date 5 March 2020

**Environmental conditions** 

Ambient temperature 8 °C

**Characteristic test data** 

Temperature of test object 8 °C

Maximum bending diameter 15(d + D)

Length of cable bended 21 m

Actual external diameter of cable	Actual diameter of cable conductor	Maximum bending diameter	Diameter of test cylinder
D	d	D <sub>r</sub>	Dt
mm	mm	mm	mm
77,5	34,4	≤ 1679	1560

#### Result

The test was carried out successfully.



# 3.3 Partial discharge test

#### Standard and date

Standard BS 7835, subclause 18.5

Test date 10 March 2020

# **Environmental conditions**

Ambient temperature 20 °C

#### **Characteristic test data**

Temperature of test object	20 °C
Circuit	direct
Calibration	10 pC
Noise level at 2,0 U₀	2,5 pC
Declared sensitivity	5
Required sensitivity	≤ 5 pC
Centre frequency	100 kHz
Bandwidth (∆f)	100 kHz
Test frequency	50 Hz
Coupling capacitor	2,6 nF

Core	Voltage applied, 50 Hz		Duration	Partial discharge level
	x U <sub>0</sub>	kV	s	pC
1	2,25	42,8	< 60	-
	2,0	38	-	Not detectable

**Note:** This PD measurement also covers the PD measurement before the bending test and therefore we have omitted the PD measurement before the bending test

#### Requirement

The magnitude of discharge on each core shall not exceed 10 pC at 2,0  $\,$ U $_{0}$ .

#### Result





# 3.4 Tan $\delta$ in relation to voltage

#### Standard and date

Standard BS 7835, subclause 21.4

Test date 11 March 2020

#### **Environmental conditions**

Ambient temperature 20 °C

#### **Characteristic test data**

Temperature of test object 20 °C Length of test object 17,41 m Standard capacitor 99,918 pF

Core	Voltage applied, 50 Hz		Capacitance of core 1) µF/km	Tan δ	Maximum increase of
	x U <sub>o</sub> kV	kV			Tan δ
1	0,5	9,5	0,33	5,3 x 10 <sup>-4</sup>	0,09 x 10 <sup>-4</sup>
	1	19	0,33	5,5 x 10 <sup>-4</sup>	
	2	38	0,33	5,4 x 10 <sup>-4</sup>	
1) for information only					

#### Requirement

The measured value shall not be higher than 40 x  $10^{-4}$  U<sub>o</sub>. The maximum increase in tan  $\delta$  from 0,5 U<sub>o</sub> to 2 U<sub>o</sub> shall not be higher than 20 x  $10^{-4}$ .

#### Result





# 3.5 Tan $\delta$ in relation to temperature

# Standard and date

Standard BS 7835, subclause 21.5

Test date 12 March 2020

#### **Environmental conditions**

Ambient temperature 20 °C

#### **Characteristic test data**

Temperature of test object 20 and 97 °C Length of test object 17,41 m Standard capacitor 99,918 pF

#### Measured at ambient temperature 20°C

Core	Voltage applied, 50 Hz	Capacitance of core 1) µF/km	Tan δ	
1	5	0,33	5,3 x 10 <sup>-4</sup>	
<sup>1)</sup> for information only				

# Measured at elevated temperature of 97 °C

Core	Voltage applied, 50 Hz	Capacitance of core 1)	Tan δ	
		μF/km		
1	5	0,30	1,2 x 10 <sup>-4</sup>	
<sup>1)</sup> for information only				

#### Requirement

The measured value shall not be higher than 40 x  $10^{-4}$  U<sub>o</sub> at ambient temperature and shall not be higher than 80 x  $10^{-4}$  at elevated temperature

#### Result

-17- 1143-20

# 3.6 Heating cycle test including partial discharge measurements

# 3.6.1 Heating cycle test

#### Standard and date

Standard BS 7835, subclause 21.6 Test date 13 to 23 March 2020

#### **Environmental conditions**

Ambient temperature 20 °C

#### **Characteristic test data**

Heating method conductor current

No. of	,		Heating cycle			
0		current during	Heating	Cooling		
cycles	temperature	steady condition		Duration of conductor at steady temperature	Total duration	
	°C	Α	h	h	h	
20	97	approx. 1895	5	2	5	

# Requirement

The test shall be carried out successfully.

#### Result





# 3.6.2 Partial discharge during and after heating cycle test

# 3.6.2.1 Partial discharge test after cycle 5

#### Standard and date

Standard BS 7835, subclause 21.6

Test date 16 March 2020

#### **Environmental conditions**

Ambient temperature 20 °C

#### **Characteristic test data**

Temperature of test object	28 °C
Circuit	direct
Calibration	10 pC
Noise level at 2,0 U <sub>0</sub>	2,5 pC
Declared sensitivity	5
Required sensitivity	$\leq$ 10 pC
Centre frequency	100 kHz
Bandwidth (∆f)	100 kHz
Test frequency	50 Hz
Coupling capacitor	2,6 nF

Core	Voltage applied, 50 Hz		Duration	Partial discharge level
	x U <sub>0</sub>	kV	s	pC
1	2,25	42,8	< 60	-
	2,0	38	-	Not detectable

#### Requirement

The magnitude of discharge on each core shall not exceed 5 pC at 2,0  $\,$ U $_{0}$ .

#### Result







# 3.6.2.2 Partial discharge test after cycle 10

#### Standard and date

Standard BS 7835, subclause 21.6

Test date 18 March 2020

#### **Environmental conditions**

Ambient temperature 20 °C

#### **Characteristic test data**

Temperature of test object	28 °C
Circuit	direct
Calibration	10 pC
Noise level at 2,0 U <sub>0</sub>	2,5 pC
Declared sensitivity	5 pC
Required sensitivity	≤ 10 pC
Centre frequency	118 kHz
Bandwidth ( $\Delta f$ )	100 kHz
Test frequency	50 Hz
Coupling capacitor	2,6 nF

Core	Voltage applied, 50 Hz		Duration	Partial discharge level
	x U <sub>0</sub>	kV	S	pC
1	2,25	42,8	<60	-
	2,0	38	-	Not detectable

# Requirement

The magnitude of discharge on each core shall not exceed 5 pC at 2,0  $\,$ U $_{0}$ .

#### Result







# 3.6.2.3 Partial discharge test after cycle 15

#### Standard and date

Standard BS 7835, subclause 21.6

Test date 20 March 2020

#### **Environmental conditions**

Ambient temperature 20 °C

#### **Characteristic test data**

Temperature of test object	29 °C
Circuit	direct
Calibration	10 pC
Noise level at 2,0 U <sub>0</sub>	3 pC
Declared sensitivity	5 pC
Required sensitivity	≤ 10 pC
Centre frequency	118 kHz
Bandwidth (∆f)	100 kHz
Test frequency	50 Hz
Coupling capacitor	2,6 nF

Core	Voltage applied, 50 Hz		Duration	Partial discharge level
	x U <sub>0</sub>	kV	S	pC
1	2,25	42,8	<60	-
	2,0	38	-	Not detectable

# Requirement

The magnitude of discharge on each core shall not exceed 5 pC at 2,0  $\,$ U $_{0}$ .

#### Result





# 3.6.2.4 Partial discharge test after cycle 20

#### Standard and date

Standard BS 7835, subclause 21.6

Test date 23 March 2020

#### **Environmental conditions**

Ambient temperature 20 °C

#### **Characteristic test data**

Temperature of test object	29 °C
Circuit	direct
Calibration	10 pC
Noise level at 2,0 U <sub>0</sub>	3 pC
Declared sensitivity	5 pC
Required sensitivity	≤ 10 pC
Centre frequency	125,5 kHz
Bandwidth ( $\Delta f$ )	100 kHz
Test frequency	50 Hz
Coupling capacitor	2,6 nF

Core	Voltage applied,	, 50 Hz	Duration	Partial discharge level
	x U <sub>0</sub>	kV	s	pC
1	2,25	42,8	<60	-
	2,0	38	-	Not detectable

#### Requirement

The magnitude of discharge on each core shall not exceed 5 pC at 2,0  $\,$ U $_{0}$ .

#### Result







# 3.7 Impulse test

#### Standard and date

Standard BS 7835, subclause 21.7

Test date 24 March 2020

**Environmental conditions** 

Ambient temperature 20 °C

**Characteristic test data** 

Temperature of test object 98 °C Specified test voltage 194 kV

Testing arrangemen	nt	Polarity	Voltage applied	No. of impulses	See figure on next pages
Voltage applied to	Earthed		(% of test voltage)		
Conductor	Metal	Positive	50	1	1 (waveshape)
	screen		65	1	2
			80	1	2
			100	10	3 and 4
Conductor	Metal	Negative	50	1	5 (waveshape)
	screen		65	1	6
			80	1	6
			100	10	7 and 8

# Requirement

The cable core shall withstand without failure 10 positive and 10 negative voltage impulses.

#### Result



#### Lightning impulse test with positive voltage




Fig. 1: Waveshape 72220708 1X 800 mm^2 Energya Cable RFW 50% (+)




Fig. 2: 72220708 1X 800 mm^2 Energya Cable RFW 65% and 80% (+)




Fig. 3: 72220708 1X 800 mm^2 Energya Cable FW 100% (+)





Fig. 4: 72220708 1X 800 mm^2 Energya Cable FW 100% (+)



#### Lightning impulse test with negative voltage



-24-

Fig. 5: Waveshape 72220708 1X 800 mm^2 Energya Cable RFW 50% (-)




Fig. 6: 72220708 1X 800 mm^2 Energya Cable RFW 65% and 80% (-)




Fig. 7: 72220708 1X 800 mm^2 Energya Cable FW 100% (-)




Fig. 8: 72220708 1X 800 mm^2 Energya Cable FW 100% (-)



-25- 1143-20

# 3.8 Four-hour voltage test

#### Standard and date

Standard BS 7835 subclause 21.8

Test date 25 March 2020

# **Environmental conditions**

Ambient temperature 20 °C

# **Characteristic test data**

Temperature of test object 20 °C

Testing arrangement		Voltage applie	ed, 50 Hz	Duration
Voltage applied to	Earth connected to	x U <sub>0</sub>	kV	h
Conductor	Metal screen	4	76	4

# Requirement

No breakdown of the insulation shall occur.

#### Result





# 3.9 Adherence of screens at short circuit temperature

# 3.9.1 Partial Discharge test subjected before short circuit current test

### Standard and date

Standard BS 7835, subclause 18.5

Test date 19 March 2020

#### **Environmental conditions**

Ambient temperature 20 °C

#### **Characteristic test data**

Temperature of test object	20 °C
Circuit	direct
Calibration	10 pC
Noise level at 2,0 U <sub>0</sub>	2 pC
Declared sensitivity	4 pC
Required sensitivity	≤ 5 pC
Centre frequency	400 kHz
Bandwidth ( $\Delta f$ )	100 kHz
Test frequency	50 Hz
Coupling capacitor	2,6 nF

Core	Voltage applied, 50 Hz		Duration	Partial discharge level
	x U <sub>0</sub>	kV	S	pC
1	2,25	42,8	<60	-
	2,0	38	-	Not detectable

#### Requirement

The magnitude of discharge on each core shall not exceed 5 pC at 2,0  $U_0$ .

#### Result



-27- 1143-20

# 3.9.2 Thermal Short-circuit test

#### Standard and date

Standard BS 7835:2007 subclause 21.9

Test date 27 March 2020

#### 3.9.2.1 Condition before test

Cable previously subjected to a partial discharge test.

Measurement of resistance:

at 20,8 °C : 978,8  $\mu\Omega$ 


at core temperature 26,4 °C : 1000,2  $\mu\Omega$ 

Current for 250 °C: 32,9 kA for 1 sec





#### **3.9.2.2** Test circuit **S01**



G = Generator TO = Test Object U = Voltage Measurement to earth

MB = Master Breaker L = Reactor I = Current Measurement

MS = Make Switch

PT = Power Transformer

Supply		
Power	MVA	97,4
Frequency	Hz	50
Phase(s)		1
Voltage	kV	2,96
Current	kA	32,9
Impedance	Ω	0,09
Power factor		< 0,1
Neutral		isolated


Load	
Short-circuit point	earthed

Remarks: -





# 3.9.2.3 Photograph before test





-30- 1143-20

#### 3.9.2.4 Test results and oscillograms

#### **Overview of test numbers**

200327-6034

#### Remarks

\_

#### **Phase indications**

If more than one phase is recorded on oscillogram, the phases are indicated by the digits 1, 2 and 3. These phases 1, 2 and 3 correspond to the phase values in the columns of the accompanying table, respectively from left to right.

#### Explanation of the letter symbols and abbreviations on the oscillograms


pu Per unit (the reference length of one unit is represented by the black bar on the oscillogram)

ITO Current through test objectUTO Voltage across test object






#### Thermal short-circuit test



#### Test number: 200327-6034

Phase	-	
Current	$kA_{peak}$	-50,2
Current, a.c. component, beginning	kA <sub>RMS</sub>	33,3
Current, a.c. component, middle	kA <sub>RMS</sub>	33,1
Current, a.c. component, end	kA <sub>RMS</sub>	33,2
Current, a.c. component, average	kA <sub>RMS</sub>	33,3
Current, a.c. component, three-phase average	kA <sub>RMS</sub>	-
Duration, current	S	1,06
Equivalent RMS value and duration		32,9 kA during 1,09 s





-32- 1143-20

# 3.9.2.5 Condition / inspection after test

Externally no visible change.


Measurement of resistance: 1189,6  $\mu\Omega$  (measured 10 minutes after test)

Observations





# 3.9.2.6 Photograph after test







# 3.9.3 Partial Discharge subjected after short circuit current test

#### Standard and date

Standard BS 7835, subclause 18.5

Test date 30 March 2020

# **Environmental conditions**

Ambient temperature 20 °C

#### **Characteristic test data**

Temperature of test object	20 °C
Circuit	direct
Calibration	10 pC
Noise level at 2,0 U <sub>0</sub>	3 pC
Declared sensitivity	5 pC
Required sensitivity	≤ 5 pC
Centre frequency	126,5 kHz
Bandwidth ( $\Delta f$ )	100 kHz
Test frequency	50 Hz
Coupling capacitor	2,6 nF

Core	Voltage applied, 50 Hz		Duration	Partial discharge level
	x U <sub>0</sub>	kV	S	pC
1	2,25	42,8	<60	-
	2,0	38	-	Not detectable

#### Requirement

The magnitude of discharge on each core shall not exceed 5 pC at 2,0  $\,$ U $_{0}$ .

#### Result





# 4 MATERIALS – TYPE TEST

# 4.1 Resistivity of semi-conducting screens

#### Standard and date

Standard BS 7835, subclause 20.3 and 20.5

Test date 1 May 2020

#### **Characteristic test data**

Temperature during ageing 100 °C Resistivity measured at 90  $\pm$  2 °C

Item	Unit	Requirement	Measured/determined
Conductor screen			
without ageing	Ωm	≤ 500	4
Insulation screen			
without ageing	Ωm	≤ 500	2

#### Result

The object passed the test.

1143-20



-36- 1143-20

# 4.2 Measurement of thickness of insulation

# Standard and date

Standard BS 7835 subclause 19.7.1, 19.7.2 and 19.8.1

Test date 7 April 2020

Item	Unit	Requirement	Specified	Measured/determined
Nominal	mm	8	8	-
Average	mm	-	-	9,37
Minimum [t <sub>min</sub> ]	mm	≥ 7,10	-	9,163
Maximum [t <sub>max</sub> ]	mm	-	-	9,706
Difference between minimum and maximum measured diameters	mm	≤ 0,5		0,5
(t <sub>max</sub> - t <sub>min</sub> ) / t <sub>max</sub>	-	≤ 0,15	-	0,06

#### Result



-37- 1143-20

# 4.3 Measurement of thickness of non-metal sheaths (including extruded separation sheaths, but excluding inner coverings)

#### Standard and date

Standard BS 7835 Subclause 19.12 and 19.15

Test date 7 May 2020

## Inner sheath/Separation sheath\*

7 - 7 - 7 - 7 - 7 - 7 - 7 - 7 - 7 - 7 -					
Item	Unit	Requirement	Calculated/ Specified	Measured/determined	
Nominal	mm	-	1,6	-	
Average	mm	-	-	2,53	
Minimum	mm	≥ 1,08	-	2,36	

#### Oversheath\*

Item	Unit	Requirement	Calculated/ Specified	Measured/determined
Nominal	mm	≥ 1,4	3,4	-
Average	mm	-	-	3,87
Minimum	mm	≥ 2,50	-	3,70

#### Note

The nominal thickness of the separation sheath and oversheath is calculated according to Subclause 13.3.3 and Annex A.}

## Result





# 4.4 Tests for determining the mechanical properties of insulation before and after ageing

## Standard and date

Standard BS 7835 Clause 20.4 Test date 31 March 2020

**KEMA** Labs

#### **Characteristic test data**

Temperature during ageing  $135 \pm 2$  °C

Ageing duration 7 x 24 h (27 March to 03 April 2020)

Item	Unit	Requirement	Measured/determined
Without ageing			
Tensile strength	N/mm <sup>2</sup>	≥ 12,5	27,2
Elongation at break	%	≥ 200	592
After ageing in air oven			
Tensile strength			
<ul> <li>value after ageing</li> </ul>	N/mm <sup>2</sup>	-	30,8
<ul><li>variation</li></ul>	%	± 25 max.	13
Elongation at break			
value after ageing	%	-	607
<ul><li>variation</li></ul>	%	± 25 max.	2

#### Result





#### Water immersion test 4.5

**KEMA** Labs

#### Standard and date

Standard BS 7835 Clause 20.13

Test date 3 April 2020

## **Characteristic test data**

 $70\pm2~^{\circ}C$ Temperature during ageing

Ageing duration 7 x 24 h (27 March to 3 April 2020)

## Oversheath

Item	Unit	Requirement	Measured/determined
Without ageing			
Tensile strength	N/mm <sup>2</sup>	≥ 10	13,0
Elongation at break	%	≥ 100	159
After ageing in air oven			
Tensile strength			
<ul> <li>value after ageing</li> </ul>	N/mm <sup>2</sup>	≥ 10	12,7
<ul> <li>variation</li> </ul>	%	± 30	-2
Elongation at break			
<ul> <li>value after ageing</li> </ul>	%	≥ 100	172
<ul><li>variation</li></ul>	%	± 30	8

#### Result



-40- 1143-20

# 4.6 Measurement for aluminium wires

## Standard and date

Standard BS 7835, Clause 19.14 20.12 Test date 7 May and 8 June 2020

Item	Unit	Requirement	Measured/determined
Without ageing			
Wire diameter	mm	2,5 ± 5%	2,58
Tensile strength	N/mm <sup>2</sup>	≥ 125	192



-41- 1143-20

# 4.7 Tests for determining the mechanical properties of non-metal sheaths before and after ageing

## Standard and date

Standard BS 7835 Clause 20.8 and 20.13

Test date 1 April 2020

#### **Characteristic test data**

Temperature during ageing  $100 \pm 2$  °C

Ageing duration 7 x 24 h (27 March to 3 April 2020)

## Inner sheath/Separation sheath

Item	Unit	Requirement	Measured/determined
Without ageing			
Tensile strength	N/mm <sup>2</sup>	≥ 4	12,3
Elongation at break	%	≥ 50	147

#### Oversheath

Item	Unit	Requirement	Measured/determined
Without ageing			
Tensile strength	N/mm <sup>2</sup>	≥ 10	13,0
Elongation at break	%	≥ 100	159
After ageing in air oven			
Tensile strength			
<ul> <li>value after ageing</li> </ul>	N/mm <sup>2</sup>	≥ 10	14,0
<ul> <li>variation</li> </ul>	%	± 40	8
Elongation at break			
<ul> <li>value after ageing</li> </ul>	%	≥ 100	132
<ul> <li>variation</li> </ul>	%	± 40	-17

#### Result





# 4.8 Compatibility test

#### Standard and date

Standard BS 7835 Clause 20.14

Test dates 31 March, 23 April and 1 May 2020

## **Characteristic test data**

Temperature during ageing 100 ± 2 °C

Ageing duration 7 x 24 h (19 March to 26 March 2020)

## **Mechanical properties**

#### Insulation

Item	Unit	Requirement	Measured/determined
Without ageing			
Tensile strength	N/mm <sup>2</sup>	≥ 12,5	27,2
Elongation at break	%	≥ 200	592
After ageing in air oven			
Tensile strength			
<ul> <li>value after ageing</li> </ul>	N/mm <sup>2</sup>	-	29,9
<ul><li>variation</li></ul>	%	± 25 max.	10
Elongation at break			
<ul> <li>value after ageing</li> </ul>	%	-	550
<ul><li>variation</li></ul>	%	± 25 max.	-7

## Inner sheath/Separation sheath

Item	Unit	Requirement	Measured/determined
Without ageing			
Tensile strength	N/mm <sup>2</sup>	≥ 4	12,3
Elongation at break	%	50	147
After ageing in air oven			
Tensile strength			
<ul> <li>value after ageing</li> </ul>	N/mm <sup>2</sup>	≥ 4	15,8
<ul><li>variation</li></ul>	%	-	28
Elongation at break			
<ul> <li>value after ageing</li> </ul>	%	50	190
<ul> <li>variation</li> </ul>	%	-	30

#### Oversheath

Item	Unit	Requirement	Measured/determined
Without ageing			
Tensile strength	N/mm <sup>2</sup>	≥ 10	13,0
Elongation at break	%	≥ 100	159
After ageing in air oven			
Tensile strength			
<ul> <li>value after ageing</li> </ul>	N/mm <sup>2</sup>	≥ 10	16,6
<ul><li>variation</li></ul>	%	± 40	28
Elongation at break			
<ul> <li>value after ageing</li> </ul>	%	≥ 100	166
<ul><li>variation</li></ul>	%	± 40	4

1143-20

-43- 1143-20

## Maximum resistivity insulation screen and conductor screen

#### **Characteristic test data**

Maximum resistivity measured at  $90 \pm 2$  °C (after 30 minutes)

Item	Unit	Requirement	Measured/determined
Conductor screen			
after ageing	Ωm	≤ 1000	13
Insulation screen			
after ageing	Ωm	≤ 1000	2

## **Cold strippability test**

#### Sample 1

Item	Unit	Requirement	Measured/Determined
After ageing	N	8 ≤ F ≤ 45	22,6 ≤ F ≤ 25,6

## Sample 2

Item	Unit	Requirement	Measured/Determined
After ageing	N	8 ≤ F ≤ 45	29,4 ≤ F ≤ 31,2

## Sample 3

Item	Unit	Requirement	Measured/Determined
After ageing	N	8 ≤ F ≤ 45	27,5 ≤ F ≤ 29,7

#### Result



-44- 1143-20

# 4.9 Pressure test at high temperature on oversheath material

## Standard and date

Standard BS 7835 Clause 20.13

Test date 15 April 2020

## **Characteristic test data**

Temperature  $80 \pm 2$  °C Heating time 6 h Load 16 N

## Oversheath

Item	Unit	Requirement	Measured/determined
Depth of indentation	%	≤ 50	17

#### Result



-45- 1143-20

## 4.10 Test for tear resistance

## Standard and date

Standard BS 7835 Clause 20.13

Test date 14 May 2020

## Oversheath

Item	Unit	Requirement	Measured/determined
Tear resistance	N/mm	≥5	8

#### Result



-46- 1143-20

# 4.11 Shrinkage test on oversheaths

## Standard and date

Standard BS 7835 Clause 20.18

Test date 17 April 2020

## Oversheath

Item	Unit	Requirement	Measured/determined
Shrinkage	%	≤ 4	2,7

#### Result



-47- 1143-20

# 4.12 Test on PVC insulation and sheaths at low temperature

#### Standard and date

Standard BS 7835 Clause 20.13

Test date 10 April 2020

#### **Characteristic test data**

Temperature  $-15 \pm 2$  °C Cooling time  $\geq 16 \text{ h}$  Mass of hammer 1500 g

## Oversheath

Item	Unit	Requirement	Measured/determined
Cold elongation test	%	≥ 30	43
Cold impact test	-	no cracks	no cracks

#### Result



-48- 1143-20

## 4.13 Hot set test for XLPE insulation

#### Standard and date

Standard BS 7835 clause 19.6

Test date 26 Mar 2020

## **Characteristic test data**

 $\begin{array}{lll} \mbox{Air temperature} & 200 \pm 3 \ ^{\circ}\mbox{C} \\ \mbox{Time under load} & 15 \ \mbox{min} \\ \mbox{Mechanical stress} & 0,2 \ \mbox{N/mm}^2 \end{array}$ 

## Insulation

Item	Unit	Requirement	Measured/determined
Elongation under load	%	≤ 175	50
Permanent elongation after cooling	%	≤ 15	-5

#### Result



-49- 1143-20

# 4.14 Water absorption test on insulation

## Standard and date

Standard BS 7835 Clause 8
Test date 24 Mar to 13 Apr 2020

## **Characteristic test data**

Temperature of water  $85 \pm 2$  °C Duration  $14 \times 24 \text{ h}$ 

Test methode Gravimetric

#### Insulation

Item	Unit	Requirement	Measured/determined
Maximum variation in mass	mg/cm <sup>2</sup>	<1	0,03

#### Result



-50- 1143-20

# 4.15 Flame spread on single cables

## Standard and date

Standard BS 7835 Clause 19.16

Test date 21 Apr 2020

## **Characteristic test data**

Overall diameter of test piece 77,3 mm Time for flame application 480 s

Flame type 1 kW pre-mixed flame

Complete cable	Unit	Requirement	Measured/determined
The distance between the lower edge of the top support and the onset of charring	mm	≥ 50	395
The distance between the lower edge of the top support and charring extends downwards to a point	mm	≤ 540	510

#### Result





# 4.16 Flame propagation on multiple cables

#### Standard and date

Standard BS 7835 Clause 20.15

Test date 15 May 2020

## **Characteristic test data**

Number of test pieces 2
The total volume of non-metallic material, per meter 3.3009
of test sample, of the test pieces
The method of mounting spaced
The number of layers 1
Flame application time 20 min
The number of burners 1

	Unit	Requirement	Measured/determined
The extent of damage;	m	< 2,5	0,36
The time to extinction of all burning or glowing	min	-	20

#### Result

The object passed the test.

1143-20



-52- 1143-20

## 4.17 Smoke emission test

#### Standard and date

Standard BS 7835 Clause 19.17

Test date 15 May 2020

## **Characteristic test data**

Diameter of the cable 69,5 mm
The number and disposition of test pieces in the test 1
sample

	Unit	Requirement	Measured/determined
Transmission level	%	60	76

#### Result







# 4.18 Corrosive and acid gas

## Standard and date

Standard BS 7835 clause 20.2

Test date 1 June 2020

## **Characteristic test data**

All non-metallic items as specified in table below.

Sample Ref.	Requirement	HCl	HF
	%	%	%
Outer sheath	0,5	< 0,024	< 0,005
Binder tape	0,5	< 0,024	< 0,005
Bedding	0,5	< 0,024	< 0,005
Semi conductive insulation screen	0,5	< 0,024	< 0,005
XLPE insulation	0,5	< 0,024	< 0,005
Semi conductive conductor screen	0,5	< 0,024	< 0,005
Tape over conductor	0,5	< 0,024	< 0,005

#### Result







# 4.19 Cold strippability

## Standard and date

Standard BS 7835 Clause 19.9.2

Test date 23 Apr 2020

## **Characteristic test data**

Temperature  $100 \pm 2$  °C Ageing duration  $7 \times 24 \text{ h}$ 

## Sample 1

Item	Unit	Requirement	Measured/Determined
Before ageing	N	8 ≤ F ≤ 45	36,5 ≤ F ≤ 38,6
After ageing	N	8 ≤ F ≤ 45	22,6 ≤ F ≤ 25,6

## Sample 2

Item	Unit	Requirement	Measured/Determined
Before ageing	N	8 ≤ F ≤ 45	38,4 ≤ F ≤ 40,2
After ageing	N	8 ≤ F ≤ 45	29,4 ≤ F ≤ 31,2

## Sample 3

Item	Unit	Requirement	Measured/Determined
Before ageing	N	8 ≤ F ≤ 45	37,0 ≤ F ≤ 38,0
After ageing	N	8 ≤ F ≤ 45	27,5 ≤ F ≤ 29,7

#### Result







## 4.20 Abrasion test

#### Standard and date

Standard BS 7835, Clause 20.17

Test date 29 April 2020

#### **Characteristic test data**

 $\begin{array}{ll} \mbox{Distance} & \geq 600 \mbox{ mm} \\ \mbox{Strokes} & 50 \mbox{ (2x 25)} \\ \mbox{Speed} & 150 \geq x \leq 300 \mbox{ mm/s} \\ \mbox{Diameter} & \geq 70 \mbox{ mm} \\ \mbox{Force} & 270 \mbox{ N} \\ \end{array}$ 

Item	Unit	Requirement	Measured/determined
Examination	-	No cracks	No cracks

#### Requirement

Examination of the sample without magnification shall reveal no cracks or splits in the internal and external surfaces.

#### Result





# 5 CHECK OF CABLE CONSTRUCTION

## Standard and date

Standard BS 7835 Clause 19.7

Test date 7 May 2020

Item	Unit	Requirement	Specified	Measured/determined
Conductor				
Diameter of conductor (d)	mm	-	34,4	34,9
Number of wires	-	≥ 53	-	61
Diameter of wires	mm	-	-	3,68-4,41 (after compacting)
Swelling yarns applied	-	-	-	no
Resistance at 20 °C	Ω/km	≤ 0,0221	-	0,0212
Semi-conducting tape				
Number of tapes	-	-	-	1
Width	mm	-	-	cannot be determined
Thickness	mm	-	-	0,35 (total thickness)
Overlap	mm	-	-	21 mm
Conductor screen				
Diameter over conductor screen	mm	-	-	37,54
Thickness	mm	-	0,5	1,07
Insulation				
Diameter over insulation	mm	-	-	56,38
Minimum diameter insulation	mm			56,156
Minimum diameter insulation	mm			56,710
Thickness	mm	7,10	8	9,37
Insulation screen				
Diameter over insulation screen	mm	-	-	58,94
Thickness	mm	-	0,5	1,25
Copper screen				
Thickness x width of tape	mm	-	0,075 x 40, 10% overlap	0,094 x 49 (10% overlap, approx.)
Inner sheath/LSHF				
Diameter over sheath	mm	-	-	64,21
Thickness	mm	-	1,08 (min.)	2,53
Aluminium wires armour				
Number of wires		-	70	74
Thickness	mm	-	2,5 ± 5%	2,58

1143-20



-57- 1143-20

Binder tape over armour				
Number of tapes			-	1
Width and thickness	mm	-	-	40 x 0,1
Overlap	%	-	-	50
Total thickness	mm	-	-	0,38 (total thickness)
Oversheath				
Diameter over oversheath	mm	-	69,5	77,33
Thickness	mm	-	2,5 (min.)	3,87
Colour	-	-	black	black

	Line 1: ENERGYA POWER CABLES-ELSEWEDY HELAL ELECTRIC CABLE Cu/XLPE/AWA/LSHF 33000 V BS 7835 1 X 800 MM2 2019 Meter marking Line 2: ELECTRIC CABLE 33000 V BS 7835}	
1) Dimensional limits do not have the status of a requirement but as a guideline only		

## Result





## 6 DRAWING



Size :	1 x 800	$mm^2$	Type :	CU/XLPE/CT/A	WA/LSHF
Voltage:	19/33	kV	Standard:	BS 7835	33
Sr.	Descrip	tion		Thickness mm	Diameter (Approx.) Mm
. Cor	mpacted Circualr	Copper Cond	ductor	111	34.4
2.	Inner Semi-C	onductive	ill (	0.5 (Nominal)	
3.	XLPE Insulation			8 (Nominal)	
4. (	Outer Semi-Conductive (Strippable)			0.5 (Nominal)	36
5. Co	Copper Tape Screen with 10% overlap			0.075 (Nominal)	
6.	LSHF Bedding			1.08 (Minimum)	
7.	Aluminum Wires Armour			$2.5 \pm 5\%$	
8.	Binder Tape			4-03-7-10-7-20-7-20-7-20-7-20-7-20-7-20-7-20	
9.	LSHF Sheath			2.5 (Minimum)	
			Not to Scale	680. 10	3.5
Prepared By			Eng. Mohamed Abdel Sattar		

Monday, 06 July, 2020 Issue, 2 Technical Offer No. 1X800 MM2 19/33KV





## 7 MEASUREMENT UNCERTAINTY

The measurement uncertainties in the results presented are as specified below unless otherwise indicated.

Measurement	Measurement uncertainty		
Dielectric tests and impulse current tests:			
peak value	≤ 3%		
time parameters	≤ 10%		
Capacitance measurement	0,3%		
Tan $\delta$ measurement	± 0,5% ± 5 x 10 <sup>-5</sup>		
Partial discharge measurement:			
< 10 pC	2 pC		
10 to 100 pC	5 pC		
> 100 pC	20%		
Measurement of impedance AC-resistance measurement	≤ 1%		
Measurement of losses	≤ 1%		
Measurement of insulation resistance	≤ 10%		
Measurement of DC resistance:			
1 to 5 μΩ	1%		
5 to 10 μΩ	0,5%		
10 to 200 μΩ	0,2%		
Radio interference test	2 dB		
Calibration of current transformers	$2.2 \times 10^{-4} I_i/I_u$ and 290 µrad		
Calibration of voltage transformers	1,6 x $10^{-4}$ U <sub>i</sub> /U <sub>u</sub> and 510 µrad		
Measurement of conductivity	5%		
Measurement of temperature:			
-50 to -40 °C	3 K		
-40 to125 °C	2 K		
125 to 150 °C	3 K		
Tensile test	1%		
Sound level measurement	type 1 meter as per IEC 60651 and ANSI S1,4,1971		
Measurement of voltage ratio	0,1%		