



DIN EN ISO 9001:2000
Zertifikat: 01 110 020214



**LABORATORIES OF EXTRA HIGH
VOLTAGE RESEARCH CENTER SECTOR**
km 27 Cairo- Alex. Desert Road
Report No.(295 /2014)
Page 1 of 20

TEST REPORT

REPORT No. (295/2014)


- **CLIENT:** : **ENERGYA POWER CABLES (ELSEWEDY HELAL).**
- **Report Date:** 30 / 12 / 2014
- **Place:**
 - Laboratories of Extra High Voltage Research Center.
 - Internal code : TO - AC - 14 - 04 - 26 - 01
- **Requirements:**
 - Loop type tests according to IEC 60840.
- **Standard Specification:**
 - IEC 60840 "Power cables with extruded insulation and their accessories for rated voltages above 30 kV ($U_m = 36$ kV) up to 150 kV ($U_m = 170$ kV).
- **Description of the Specimen :**
 - Loop systems, cable and accessories consist of the following:

1- 38/66 kV Power cable with the following specification:

- Manufacturer : **ENERGYA POWER CABLES(ELSEWEDY HELAL)EETC.**
- Type : 38/66 kV/CU/XLPE/LEAD/HDPE /1 x 1200 mm²
- No. of Phases : 1
- Insulation : XLPE
- Conductor Material : Copper + Swelling Powder
- Conductor cross-section : 1200 mm²
- Metallic sheath Material : Lead
- Over sheath Material : HDPE (ST7)
- Sheath Color : Black
- Water Penetration Design : A barriers are included which prevents longitudinal water penetration (water blocking tape):

Along the outer surface of the conductor,

The gap between the outer surface of the insulation screen and the metallic screen.



M. Ruben



DIN EN ISO 9001:2000
Zertifiziert: 01.11.0020214



LABORATORIES OF EXTRA HIGH
VOLTAGE RESEARCH CENTER SECTOR
KM 27 Cairo- Alex. Desert Road
Report No.(295 /2014)
Page 2 of 20

2- One 38/66 kV Porcelain outdoor cable termination with the following specifications:

- Manufacturer : EL SEWEDY SEDCO.
- Type : SEPT 1-72
- Creepage distance : 2970 mm.
- Arc distance : 930 mm.
- No. of sheds : 13 large and 12 small.
- Greatest diameter : 325 mm.
- Termination housing material: Porcelain.
- Filling compound : Silicon oil.
- Base and top : Aluminum.
- Stress control material : EPDM.
- Gaskets : O-ring

3- One 38/ 66 kV straight cable joint with the following specifications:

- Manufacturer : EL SEWEDY SEDCO.
- Type : 69TCJ.
- Description of joint : Premolded joint.
- Method of ground : Lead cover .
- Type of overall casing : Heat shrink tube.
- Connector type : Compression.
- Type of insulation : EPDM

4- One 66 kV Premolded outdoor cable termination with the following specifications:

- Manufacturer : EL SEWEDY SEDCO.
- Type : 69 TCT
- Creepage distance : 2640 mm.
- Arc distance : 1105 mm.
- No. of sheds : 8 large and 7 small
- Greatest diameter : 325 mm.
- Termination housing material: Premolded.
- Modular material : EPDM.
- Stress control material : EPDM.





DIN EN ISO 9001:2000
Zertifizierungsnummer: 01 100 026214



**LABORATORIES OF EXTRA HIGH
VOLTAGE RESEARCH CENTER SECTOR**
kM 27 Cairo- Alex. Desert Road
Report No.(295 /2014)
Page 3 of 20

▪ **Description of the Equipment:**

- High voltage reactor – 400 kV – 5000 kVA – 50 Hz – Type: (RSK) – Serial No. 204322/99.
- PD detector – Type: (TE57).
- Tan δ measurement devise – Type: 254/321/02 Serial No. 144281.
- Standard capacitor – Type: NK400 Serial No. 434321.
- Impulse voltage generator 800 kV – 40 kJ – Type IP40/ 800 m
- Air oven up to 300 °C – Type: BINDER - Serial No. 02-32772.
- Universal testing machine 100 kN - Model APEX-T5000 Serial No. 2095.

▪ **Test Samples:**

- Test samples were chosen under the responsibility of the client.

▪ **Tests:**

1. Electrical Type Tests

- 1.1 Check of insulation thickness of cable for electrical type tests
- 1.2 Bending test on the cable followed by installation of accessories and partial discharge test at ambient temperature.
- 1.3 *Tan δ* measurement.
- 1.4 Heating cycle voltage test.
- 1.5 Partial discharge test:
 - At ambient temperature.
 - At high temperature
- 1.6 Lightning impulse voltage test followed by a power frequency voltage test.
- 1.7 Tests of outer protection for buried joint.
- 1.8 Resistivity of semi-conducting screens.
- 1.9 Examination of the test assembly.

2. Non-Electrical Type Tests:

- 2.1 Check of cable construction.
- 2.2 Tests for determining the mechanical properties of insulation before and after ageing
- 2.3 Tests for determining the mechanical properties of non-metallic sheaths before and after ageing
- 2.4 Ageing tests on pieces of complete cable to check compatibility of materials
- 2.5 Hot set test for XLPE insulation.
- 2.6 Shrinkage test for XLPE insulation.
- 2.7 Water penetration test.
- 2.8 Measurement of Carbon Black Content

M. Per...



DIN EN ISO 9001:2000
Zertifiziert: 01 110 026214



**LABORATORIES OF EXTRA HIGH
VOLTAGE RESEARCH CENTER SECTOR**
kM 27 Cairo- Alex. Desert Road
Report No.(295 /2014)
Page 4 of 19

▪ **Test Method and Results:**

1- Electrical Type Tests:

1.1 Check on insulation thickness before electrical type tests:

- Prior to the electrical type tests the insulation thickness was measured in accordance with clause 11.3.1 of IEC 60840.
- The measured value of the insulation thickness is shown in the following table:

Average thickness (mm)	Specified thickness (mm)	Requirement
17.231	17	The average thickness of the insulation doesn't exceed the specified value by more than 5%

1.2 Bending test on the cable followed by partial discharge test:

1.2.1 Bending test:

- The test cable was subjected to a bending test at ambient temperature in accordance with clause 12.3.4 of IEC 60840. The test cable was bent around a test cylinder. The diameter of the cylinder was 2.8 m. The test consisted of three cycles. The test object was bent for one complete turn. It was then unwound. The process repeated, except that the bending of the sample was in the reverse direction..

Outer diameter of cable D (mm)	Diameter of conductor d (mm)	Requirement of bending diameter <math>< 25(D+d)+5\%</math> (mm)	Hub diameter of drum (mm)
98	43.6	<math>< 3717</math>	2800

1.2.2 Partial discharge test:

- After bending test the terminations were installed on the cable and the test assembly was subjected to a partial discharge test at ambient temperature in accordance with clause 12.4.4 of IEC 60840. The test voltage was raised gradually to and held at $1.75 U_0$ for 10 s and then slowly reduced to $1.5 U_0$.
- The measured value of the partial discharge level is shown in the following table

Applied voltage (kV)	Duration (S)	Max. PD level (PC)	PD level (PC)
66.5	10	--	--
57	--	≤ 5	1.8

- *The test results met the requirements.*



DIN EN ISO 9001:2000
Zertifiziert: 01 110 020214



LABORATORIES OF EXTRA HIGH
VOLTAGE RESEARCH CENTER SECTOR
KM 27 Cairo- Alex. Desert Road

Report No.(295 /2014)

Page 5 of 20

1.3 Tan δ measurement:

- Another sample test cable was subjected to a tanδ measurement in accordance with clause 12.4.5 of IEC 60840. The test assembly was heated by passing a current through the conductor until it reached a steady temperature, which was 97 °C. The tan δ was measured at a power frequency voltage of U_0 at the temperature specified above.
- The measured value of the partial discharge level is shown in the following table

Applied voltage (kV)	Maximum allowable value for $\tan \delta$ ($\times 10^{-4}$)	$\tan \delta$ ($\times 10^{-4}$) [Measured value]
38	10	4

- *The test results met the requirements.*

1.4 Heating Cycle Voltage Test:

- The test assembly was subjected to a heating cycle voltage test in accordance with clause 12.4.6 of IEC 60840. The test assembly was heated by passing a current through the conductor until it reached a steady temperature, which was 97 °C. The heating was applied for 8 h. The conductor temperature was maintained within the stated temperature limits for 2 h of each heating period. This was followed by 16 h of natural cooling. The cycle of heating and cooling was carried out 20 times. During the whole of the test period a voltage of $2U_0$ was applied to the test object.
- The result of the heating cycle voltage test is shown in the following table.

No. of heating cycles	Required conductor temperature (°C)	Heating		Cooling time (h)	Applied voltage continuously (kV)
		Total heating time (h)	Duration of heating at 97 °C (h)		
20	$95 \leq t \leq 100$	8	2	16	76

- *The test results met the requirements.*

1.5 Partial discharge test:


1.5.1 At ambient temperature:

- After the last heat cycle, partial discharge was measured for the test assembly at ambient temperature in accordance with clause 12.4.6 of IEC 60840. The measurement was carried out as mentioned above under item 1.2.2. The measured value of the partial discharge level is shown in the following table.

Applied voltage (kV)	Duration (S)	Max. PD level (PC)	PD level (PC)
66.5	10	--	--
57	--	≤ 5	1.9

- *The test results met the requirements.*

M. Rabie





DIN EN ISO 9001:2000
Zertifiz. Nr. 01 100 020214



**LABORATORIES OF EXTRA HIGH
VOLTAGE RESEARCH CENTER SECTOR**
kM 27 Cairo- Alex. Desert Road
Report No.(295 /2014)
Page 6 of 20

1.5.2 At high temperature:

- After test assembly was subjected to a partial discharge test at ambient temperature, partial discharge was measured for the test assembly at the conductor temperature 97°C in accordance with clause 12.4.6 of IEC 60840. The measurement was carried out as mentioned above under item 2.2.
- The measured value of the partial discharge level is shown in the following table:

Applied voltage (kV)	Duration (S)	Max. PD level (PC)	PD level (PC)
66.5	10	--	--
57	--	≤ 5	1.8

- *The test results met the requirements.*

1.6 Lightning impulse voltage test followed by a power frequency voltage test:

1.6.1 Lightning impulse voltage test:

- The test assembly was subjected to a lightning impulse voltage withstand test in accordance with clauses 12.4.7 of IEC 60840. The test was performed on the test assembly at a conductor temperature of 97 °C. The cable withstood 10 positive and 10 negative voltage impulses with crest value of 325 kV without failure.
- The results were illustrated by the Figures in pages No. (13 : 16) of this report.
- *The test results met the requirements.*

1.6.2 Power frequency voltage test:

- After the impulse voltage test, the test assembly was subjected to power frequency voltage test of $2.5U_0$ for 15 min. in accordance with clause 12.4.7 of IEC 60840.
- The result of the power frequency voltage test is shown in the following table

Applied voltage (kV)	Frequency (Hz)	Duration (min)	Observations
95	50	15	No breakdown

- *The test results met the requirements.*

M. Rabu



DIN EN ISO 9001:2000
Zertifiziert: 01 110 020214



**LABORATORIES OF EXTRA HIGH
VOLTAGE RESEARCH CENTER SECTOR**
KM 27 Cairo- Alex. Desert Road
Report No.(295 /2014)
Page 7 of 20

1.7 Tests of outer protection for buried joints

- After completion the above tests the isolated joint that still on the cable was immersed in water to a depth of 1m at the highest point of the outer protection in accordance with clause G.3 (Annex G) of IEC 60840. The total of 7 heating/cooling cycles was applied by raising the water temperature to 77°C and maintained at this temperature for 5 hours and then permitted to cool to 10 °C above the ambient temperature. The result of the test is shown in the following table :

Water immersion and heat cycling		
No. of heating cycles	Required water temperature (°C)	Duration of heating at 77 °C (h)
20	$70 \leq t \leq 75$	5

- After completion the heating cycles and with the joint still immersed in the water, the following tests were carried out:

a- DC voltage test:


- The test voltage of 25 kV d.c. was applied for 5 min. in accordance with Annex G of IEC 60840 between the metallic sheath (Lead) of the power cable, at either end of the accessory and also between the metallic sheath and the earthed exterior of the joint outer protection (the water). The result of the test is shown in the following table:

d. c voltage test		
Applied voltage (kV)	Duration (min)	Observations
25	1	No breakdown

- *The test results met the requirements.*

b- Impulse voltage test

- After completion the DC voltage test the isolated joint that still on the cable was immersed in water, the joint withstood 10 positive and 10 negative voltage impulses with crest value of 60 kV between the metallic sheath and the earthed exterior of the joint outer protection (the water) without failure.
- The results were illustrated by the Figures in pages No. (16 :19) of this report.
- *The test results met the requirements.*





DIN EN ISO 9001:2000
Zertifikat: 01 100 020214



**LABORATORIES OF EXTRA HIGH
VOLTAGE RESEARCH CENTER SECTOR**
km 27 Cairo- Alex. Desert Road
Report No.(295 /2014)
Page 8 of 20

1.8 Resistivity of semi-conducting screens:

- The measurement of the resistivity of the semi-conducting screens was carried out in accordance with clause 11.3.9 of IEC 60840. The resistivity of extruded semi-conducting screens applied over the conductor and over the insulation was determined by measurements on test pieces taken from the core of a sample of cable as manufactured and a sample of cable which has been subjected to the ageing treatment to test the compatibility of component materials specified in IEC 60840. The measurements were made at a temperature of 90 °C.
- The resistivity of the semi-conducting screens are shown in the following table:

Item	Unit	Requirement	Measured / Determined
Conductor screen			
- without ageing	Ωm	≤ 1000	25.4
- after ageing	Ωm	≤ 1000	12.4
Insulation screen			
- without ageing	Ωm	≤ 500	16.4
- after ageing	Ωm	≤ 500	9.1

- *The test results met the requirements.*

1.9 Examination of the test assembly.


- The examination of the terminations was carried out after completion of the electrical type test mentioned above in accordance with clause 12.3.2 of IEC 60840.
- The terminations were revealing no signs of degradation, leakage, corrosion or harmful shrinkage.
- *The test results met the requirements.*

2- Non-Electrical Type Tests:

2.1. Check of Cable Construction:

- The examination of the conductor and measurements of insulation and sheath thickness was carried out in accordance with clause 12.5.1 of IEC 60840. The results are shown in the following table:

M. R. R. R.





DIN EN ISO 9001:2000
Zertifizierten: 01 110 020214



LABORATORIES OF EXTRA HIGH
VOLTAGE RESEARCH CENTER SECTOR
kM 27 Cairo- Alex. Desert Road

Report No.(295 /2014)

Page 9 of 19

No.	Items	Unit	requirement	Measured Values
1	Cable Marking			1 x 1200 mm ² 38/66 kV - CU/XLPE/LEAD/HD PE EETC 2014
2	Color of the outer sheath		Black	Black
3	Conductor: - Material - Diameter (Av.) - Number of wires	mm No.	≥ 43.6	Copper 43.6 61
4	Extruded Inner semi-conducting material - thickness (Av.)	mm	---	1.53
5	XLPE Insulation - minimum thickness - $(t_{max} - t_{min}) / t_{max}$	mm	≥ 15.3 ≤ 0.15	17.53 0.062
6	Extruded Outer semi-conducting material - thickness (Av.)	mm	---	1.29
7	Diameter over insulation	mm	---	
8	Semi-conductive water blocking tape - Thickness (Av.)	mm		0.54
9	Metallic sheath - material - minimum thickness	mm	≥ 2.085	Lead 2. 632
10	Oversheath - material - diameter (Av.) - minimum thickness.	mm mm	≥ 2.875	High Density Poly Ethylene (HDPE) - ST ₇ 98 3.69
11	Semi - conductive layer graphite powder	mm	---	0.05

- The test results met the requirements.

2.2. Tests for determining the mechanical properties of insulation before and after ageing:

- The mechanical properties of insulation before and after ageing were determined in accordance with clause 12.5.2 of IEC 60840.
- The results of the mechanical properties of insulation before and after ageing are.



DIN EN ISO 9001:2000
Zertifizierungsnummer: 01 100 020214



LABORATORIES OF EXTRA HIGH
VOLTAGE RESEARCH CENTER SECTOR
Km 27 Cairo- Alex. Desert Road

Report No.(295 /2014)

Page 10 of 20

- shown in the following table:

Item	Unit	Requirement	Measured/ Determined
Without ageing			
-Min. tensile strength	N/mm ²	12.5	23.34
-Min. elongation at break	%	200	401.2
after ageing in air oven			
-Min. tensile strength	N/mm ²	---	19.65
-Max. variation with samples without ageing	%	± 25	15.80
-Min. elongation at break	%	---	452.1
-Max. variation with samples without ageing	%	± 25	-12.68

- *The test results met the requirements.*

2.3. Tests for determining the mechanical properties of non-metallic sheaths before and after ageing:

- The mechanical properties of the outer sheath before and after ageing were determined in accordance with clause 12.5.3 of IEC 60840.
- The results of the mechanical properties of non-metallic sheaths before and after ageing are shown in the following table:

Item	Unit	Requirement	Measured / determined
Without ageing			
-Min. tensile strength	N/mm ²	12.5	25.31
-Min. elongation at break	%	300	436
after ageing			
-Min. elongation at break	%	300	380

- *The test results met the requirements.*

2.4. Ageing Tests on Pieces of Completed Cable to Check Compatibility of Materials:

- Ageing tests on pieces of completed cable were carried out in accordance with clause 12.5.4 of IEC 60840.
- The results of the mechanical properties of completed cable are shown in the following table:

Item	Unit	Requirement	Measured /determined
Insulation			
-Min. tensile strength	N/mm ²	----	19.96
-Max. variation with samples without ageing	%	± 25	14.48
-Min. elongation at break	%	----	354.1
-Max. variation with samples without ageing	%	± 25	11.73
Sheath			
- Min. elongation at break	%	300	456

- *The test results met the requirements.*

M. Ruben

2.5. Hot set test for XLPE insulation:

- A hot set test for the XLPE insulation was carried out in accordance with clause 12.5.10 of IEC 60840.
- The results of the hot set test for the XLPE insulation are shown in the following table:

Item	Unit	Requirement	Measured
-elongation under load	%	≤ 175	125
-permanent elongation	%	≤ 15	8.2

- *The test results met the requirements.*

2.6. Shrinkage test for XLPE insulation

- A shrinkage test for XLPE insulation was carried out in accordance with clause 12.5.16 of IEC 60840.
- The result of the shrinkage test for XLPE insulation is shown in the following table.

Distance L (mm)	Air oven temp. (°C)	Duration (hour)	Max. shrinkage (%)	Shrinkage measurement (%)
200	130	6	4	1.25

- *The test results met the requirements.*

2.7. Water penetration test :

- *The test has been carried out a new sample have the same dimensions with marking (Energya Power Cables)*
- The water penetration test was carried out in accordance with clause 12.5.14 of IEC 60840. In total 6m cable was used for this test. The cable was tested for longitudinal water tightness along the conductor, the outer surface of the conductor, and the gap between the outer surface of the insulation screen and the metallic screen.

No. of heating cycles	Required conductor temp. (°C)	Heating		Cooling time (h)
		Total heating time (h)	Duration at 98 °C (h)	
10	$95 \leq t \leq 100$	8	2	16

- After completion of the 10 heating cycles no water emerged from the ends of the cable
- *The test results met the requirements.*

2.8. Measurement of Carbon Black Content :

- Measurement of carbon black content for HDPE was carried out in accordance with clause (12.5.12) of IEC (60840).
- The test results are shown in the following table :



DIN EN ISO 9001:2000
Zertifiz. Nr. 01 100 020214



**LABORATORIES OF EXTRA HIGH
VOLTAGE RESEARCH CENTER SECTOR**
kM 27 Cairo- Alex. Desert Road
Report No.(295 /2014)
Page 18 of 20

Premold Joint Type: 69 TCJ For 1200mm² Power Cable, ELSEWEDY SEDCO

Polarity: (+ve)

TO-AC-14-04-26-01




Fig. 6

Ch1: 1
Up = 60.184 kV
T1 = 1.3081 μ s
T2 = 50.439 μ s




Fig. 7

Ch1: 1
Up = 60.217 kV
T1 = 1.3076 μ s
T2 = 50.452 μ s




Fig. 8

Ch1: 1
Up = 60.194 kV
T1 = 1.3012 μ s
T2 = 50.461 μ s




Fig. 9

Ch1: 1
Up = 60.114 kV
T1 = 1.3006 μ s
T2 = 50.579 μ s





Fig. 10

Ch1: 1
Up = 60.228 kV
T1 = 1.3069 μ s
T2 = 50.480 μ s





DIN EN ISO 9001:2000
Zertifiziert: 01 100 020214



**LABORATORIES OF EXTRA HIGH
VOLTAGE RESEARCH CENTER SECTOR**
kM 27 Cairo- Alex. Desert Road
Report No.(295 /2014)
Page 12 of 19

Item	Requirement	Measured
Carbon black content	2.5 + 0.5	2.15

- *The test results met the requirements.*

■ **Conclusion :**

- *The loop system, 38/66 kV Power cable - CU/XLPE/CW/LEAD/HDPE /1× 1200 mm² manufactured by Energya Power Cables (El Sewedy Helal) , 66 kV Porcelain outdoor cable termination manufactured by EL SEWEDY SEDCO , , 66 kV straight & isolated cable joint manufactured EL SEWEDY SEDCO ,and 66 kV Premolded outdoor cable termination manufactured EL SEWEDY SEDCO fulfilled the requirements of tests mentioned in this report according to IEC 60840(2011).*

- **Notes:**

- Tests were carried out on the above specimens only without any responsibility concerning other untested specimens.
- The tests were carried out without any obligation on Egyptian Electricity Holding Company.
- This test report shall not be reproduced except in full, without written approval of EHVRC.

■ **TEST ENGINEERS:**

M. Rabie

*M. Abd. Elsayed
24/1/2015*

SECTOR HEAD



2015



DIN EN ISO 9001:2000
Zertifikat: 01 100 020214



LABORATORIES OF EXTRA HIGH VOLTAGE RESEARCH CENTER SECTOR
kM 27 Cairo-Alex. Desert Road
Report No.(295 /2014)
Page 13 of 20

38/66 KV Power Cable CU/XLPE/LEAD/HDPE, 1200mm², Energya Cables

Polarity: (+ve)

TO-AC-14-04-26-01




Fig. 1

Ch1: 1
 Up = 321.63 kV
 T1 = 3.5960 μs
 T2 = 55.072 μs




Fig. 2

Ch1: 1
 Up = 321.72 kV
 T1 = 3.6071 μs
 T2 = 54.990 μs




Fig. 3

Ch1: 1
 Up = 321.86 kV
 T1 = 3.6088 μs
 T2 = 55.010 μs




Fig. 4

Ch1: 1
 Up = 321.76 kV
 T1 = 3.5985 μs
 T2 = 55.043 μs





Fig. 5

Ch1: 1
 Up = 321.80 kV
 T1 = 3.6052 μs
 T2 = 55.035 μs





DIN EN ISO 9001:2000
Zertifiz. Nr. 01 100 026214



LABORATORIES OF EXTRA HIGH VOLTAGE RESEARCH CENTER SECTOR
kM 27 Cairo- Alex. Desert Road
Report No.(295 /2014)
Page 19 of 20

Premold Joint Type: 69 TCJ For 1200mm² Power Cable, ELSEWEDY SEDCO

Polarity: (-ve)

TO-AC-14-04-26-01




Fig. 1

Ch1: 1
Up = -59.658 kV
T1 = 1.3255 μs
T2 = 50.601 μs




Fig. 2

Ch1: 1
Up = -59.724 kV
T1 = 1.3012 μs
T2 = 50.525 μs




Fig. 3

Ch1: 1
Up = -59.724 kV
T1 = 1.3001 μs
T2 = 50.597 μs




Fig. 4

Ch1: 1
Up = -59.742 kV
T1 = 1.3005 μs
T2 = 50.572 μs




Fig. 5

Ch1: 1
Up = -59.793 kV
T1 = 1.2983 μs
T2 = 50.478 μs





DIN EN ISO 9001:2000
Zertifiziert: 01 110 026214



LABORATORIES OF EXTRA HIGH VOLTAGE RESEARCH CENTER SECTOR
kM 27 Cairo- Alex. Desert Road
Report No.(295 /2014)
Page 14 of 20

38/66 KV Power Cable CU/XLPE/LEAD/HDPE, 1200mm², Energya Cables

Polarity: (+ve)

TO-AC-14-04-26-01




Fig. 6

Ch1: 1
Up = 321.86 kV
T1 = 3.6046 μs
T2 = 55.066 μs




Fig. 7

Ch1: 1
Up = 321.93 kV
T1 = 3.6149 μs
T2 = 55.045 μs




Fig. 8

Ch1: 1
Up = 321.92 kV
T1 = 3.6132 μs
T2 = 55.072 μs




Fig. 9

Ch1: 1
Up = 321.94 kV
T1 = 3.6150 μs
T2 = 55.081 μs




Fig. 10

Ch1: 1
Up = 321.72 kV
T1 = 3.6083 μs
T2 = 55.090 μs





DIN EN ISO 9001:2000
Zertifikat: 01 100 026214



LABORATORIES OF EXTRA HIGH
VOLTAGE RESEARCH CENTER SECTOR
KM 27 Cairo- Alex. Desert Road

Report No.(295 /2014)

Page 15 of 20

38/66 KV Power Cable CU/XLPE/LEAD/HDPE, 1200mm², Energya Cables

Polarity: (-ve)

TO-AC-14-04-26-01




Fig. 1

Ch1: 1
Up = -321.88 kV
T1 = 3.5995 μs
T2 = 55.065 μs




Fig. 2

Ch1: 1
Up = -321.89 kV
T1 = 3.5968 μs
T2 = 55.072 μs




Fig. 3

Ch1: 1
Up = -321.93 kV
T1 = 3.6006 μs
T2 = 55.069 μs




Fig. 4

Ch1: 1
Up = -321.86 kV
T1 = 3.5952 μs
T2 = 55.122 μs




Fig. 5

Ch1: 1
Up = -321.90 kV
T1 = 3.6004 μs
T2 = 55.108 μs

Mikhaem



DIN EN ISO 9001:2000
Zertifiz. Nr. 01 100020214



**LABORATORIES OF EXTRA HIGH
VOLTAGE RESEARCH CENTER SECTOR**
kM 27 Cairo- Alex. Desert Road
Report No.(295 /2014)
Page 20 of 20

Premold Joint Type: 69 TCJ For 1200mm² Power Cable, ELSEWEDY SEDCO
Polarity: (-ve)

TO-AC-14-04-26-01




Fig. 6

Ch1: 1
Up = -59.785 kV
T1 = 1.2985 μs
T2 = 50.498 μs




Fig. 7

Ch1: 1
Up = -59.802 kV
T1 = 1.2972 μs
T2 = 50.476 μs




Fig. 8

Ch1: 1
Up = -59.810 kV
T1 = 1.2997 μs
T2 = 50.456 μs




Fig. 9

Ch1: 1
Up = -59.774 kV
T1 = 1.2973 μs
T2 = 50.520 μs





Fig. 10

Ch1: 1
Up = -59.661 kV
T1 = 1.2950 μs
T2 = 50.500 μs





DIN EN ISO 9001:2000
Zertifikat: 01 100 020214



LABORATORIES OF EXTRA HIGH
VOLTAGE RESEARCH CENTER SECTOR
km 27 Cairo- Alex. Desert Road

Report No.(295 /2014)

Page 16 of 20

38/66 KV Power Cable CU/XLPE/LEAD/HDPE, 1200mm², Energya Cables

Polarity: (-ve)

TO-AC-14-04-26-01




Fig. 6

Ch1: 1
Up = -321.95 kV
T1 = 3.5974 μs
T2 = 55.113 μs




Fig. 7

Ch1: 1
Up = -321.96 kV
T1 = 3.6046 μs
T2 = 55.092 μs




Fig. 8

Ch1: 1
Up = -321.94 kV
T1 = 3.6037 μs
T2 = 55.099 μs




Fig. 9

Ch1: 1
Up = -321.83 kV
T1 = 3.5958 μs
T2 = 55.170 μs





Fig. 10

Ch1: 1
Up = -321.83 kV
T1 = 3.5998 μs
T2 = 55.184 μs





DIN EN ISO 9001:2004
Zertifikat: 01 100 020214



LABORATORIES OF EXTRA HIGH
VOLTAGE RESEARCH CENTER SECTOR

kM 27 Cairo- Alex. Desert Road

Report No.(295 /2014)

Page 17 of 20

Premold Joint Type: 69 TCJ For 1200mm² Power Cable, ELSEWEDY SEDCO

Polarity: (+ve)

TO-AC-14-04-26-01




Fig. 1

Ch1: 1
Up = 59.962 kV
T1 = 1.3045 μs
T2 = 50.678 μs




Fig. 2

Ch1: 1
Up = 60.195 kV
T1 = 1.3080 μs
T2 = 50.458 μs




Fig. 3

Ch1: 1
Up = 60.115 kV
T1 = 1.3010 μs
T2 = 50.531 μs




Fig. 4

Ch1: 1
Up = 60.210 kV
T1 = 1.3073 μs
T2 = 50.428 μs





Fig. 5

Ch1: 1
Up = 60.186 kV
T1 = 1.3022 μs
T2 = 50.459 μs

CONSTRUCTION DATA

1X1200 mm² XLPE, CU. 66kv




<i>Size</i> : 1 x 1200 mm ²		<i>Type</i> : Cu/XLPE/LEAD/HDPE	
<i>Voltage</i> : 38 / 66 kV		<i>Standard</i> : IEC 60502, 60811, 60840	
<i>Code</i> : P-MT31-X9-01-PH		<i>Enrgya Power CABLES</i>	
<i>Sr.</i>	<i>Description</i>	<i>Thickness mm</i>	<i>Diameter mm</i>
1.	Copper Conductor + Swelling Powder		43.6 (Approx.)
2.	Non-Conductive Water Blocking Tape		
3.	Semi-Conductive Water Blocking Tape/ 30% O.L	0.2	44.4
4.	Inner Semi-Conductive	1.53	
5.	XLPE Insulation	17.53	
6.	Outer Semi-Conductive	1.29	
7.	Semi-Conductive Water Blocking Tape/30% O.L	0.54	
8.	Lead Alloy Sheath	2.632	
9.	HDPE Sheath	3.69	
10.	Semi-Conductive Layer – Graphite powder	0.05	Approx. 98
Not to Scale			

مرکز ابحاث الجهد العالي

سرق رقم / ٥١٢

لتقرير الفني رقم ١٠٠٩٥٥




- 1- Cable outer semi conductive
- 2- Heat shrink tubing
- 3- Lead cover
- 4- Crimping connector
- 5- Housing insulation
- 6- Cable insulation
- 7- Heat sink

- 8- Cable outer jacket
- 9- Semi conductive insert
- 10- Lead sheath
- 11- Mastic tape
- 12- Plumbing
- 13- Housing outer semi conductive

* Test rating according to IEC 60840
 * Joint applicable for C.S.A up to 1200mm² and diameter over insulation up to 82mm.

سرکار ايجات الجهد العالي
 سابق رقم / ٥١٢
 لتوريد القابض رقم ٥١٤٠٩٥

Date 9/4/2014		Checked by A.Refai		Approved by A.Refai		All dimensions are in millimeters	
Drawn by A.Abdelrhman		A.Refai		A.Refai		66KV cable accessories	
ELSEWEDY		S E D C O		Premold joint		Edition	
Subsidiary of Elsewedy Electric				69 TCJ		Sheet 1	



- 1- Cable lug.
- 2- Lug sealing.
- 3- Cable insulation.
- 4- Premolded module.
- 5- Termination base.
- 6- Stress control part.
- 7- Cable outer semi conductive.

- 8- Mastic tape.
- 9- Heat shrink tube
- 10- Cable outer jacket
- 11- Copper braid
- 12- Grounding wire
- 13- Earthing lug


- Test rating according to IEC 60840
- Termination applicable for C.S.A up to 1200mm² and diameter over insulation up to 82mm
- Min. Creepage distance (C) = 2640 mm
- Flush over distance (F) = 1105 mm

مركز أبحاث الهندسة
 رقم راسم / ٤
 لتوريد النسخ رقم ١٩٥
 ١٤/٢٠


Date 9/4/2014		All dimensions are in mm.	
Drawn by A. Abdelrahman	Checked by A. Refai	Approved by A. Refai	66KV cable accessories
EISEWEDY S E D C O		Premolded termination	
Subsidiary of Eisewedy Electric		69 TCT	
		Edition 1	
		Scale NTS	
		Sheet 1/1	

Legend:

- 1- Compression Top bolt lug
- 2- Lug sealing
- 3- AL cap
- 4- AL half rings
- 5- Porcelain insulator
- 6- EPDM stress cone
- 7- Silicon oil
- 8- Aluminum base
- 9- Metallic base
- 10- post insulator (optional)
- 11- Cu earthing tube
- 12- Heat shrink tube
- 13- Cable insulation
- 14- Cable semi conductor layer
- 15- Gasket
- 16- Earthing point
- 17- Cable outer jacket



شركة إيجان الهندسة
 رقم ر.د.م. ٥٠٥
 الجدة - جدة ٢١٥٠٠
 ٢٠١٤



- * For outdoor termination Arcing horn and corona ring can be supplied upon request
- * Test rating according to IEC 60840.
- * Termination applicable for C.S.A up to 1200mm² and diameter over insulation up to 82mm
- * Min. Creepage distance (C) = 2970 mm
- * Flash over distance (F) = 930 mm

Date 30/3/2014			All dimension in mm	
drawn by A.Abdelrahman	checked by A.Refai	approved by A.Refai	66KV cable accessories	Scale NTS
ELSEWEDY S E D C O Subsidiary of Elsewedy Electric			Porcelain termination	Edition 1
			SEPT1- 72	Sheet 1